



2022 LONG TERM PASA: RELIABILITY ASSESSMENT

13 April 2022

Contents

- WEM Rules context
- Approach
 - Unserved energy simulation overview
 - EUE assessment
 - Availability Class requirements



WEM Rules context – scope of Reliability Assessment

WEM Rule 4.5.9: Planning Criterion


- a) Forecast peak component: 10% POE peak + Min Freq Keeping (MFK) + Reserve Margin (RM) + Intermittent Load allowance
- b) Reliability component: Capacity sufficient to limit Expected Unserved Energy (EUE) to 0.002% of expected demand

Reserve Capacity Target (RCT) = Max(a, b)

WEM Rule 4.5.12: Availability Class requirements

- b) Min Availability Class 1 requirement:
- All Availability Class 2 capacity dispatched to minimise peak demand
- Outage evaluation criteria satisfied (capacity margin)
- Planning Criterion satisfied (i.e. EUE < 0.002% of annual expected demand)
- c) Max Availability Class 2 requirement: RCT minus Availability Class 1 requirement







APPROACH



Simulating Unserved Energy - overview

Key modelling output is estimate of Unserved Energy, simulated using bespoke model (CAPSIM)

Forecast load for each hour for each year of LT PASA horizon



Five sets of hourly traces calculated using five different historical load shapes (load scenarios)

Calculate Unconstrained **Available Capacity**



Apply SCED constraints

Equals total capacity less Planned Outages less randomly simulated Forced Outages. Scaled to reflect RCT in each Capacity Year.

Calculate Constrained Available Capacity



Equals Unconstrained Available Capacity less SCED curtailments

Calculate Unserved Energy for each year of LT PASA horizon



Hourly Unserved Energy equals (3) minus (1)



Annual Unserved Energy equals sum of hourly estimates

Is simulated 50 times (random forced outage seeds) per load scenario (11) -> 250 estimates of Unserved Energy

Calculate Expected Unserved Energy




Average 250 Annual Unserved Energy estimates



1 Load Forecast

- Based on AEMO's peak (MW) and annual consumption (MWh) forecast. Three scenarios modelled:
 - 50% POE peak and expected consumption
 - 10% POE peak and expected consumption
 - 10% POE peak and high consumption
- To convert AEMO's load forecasts into hourly load traces, we need to model how that load will be spread out over the year and when the peaks will occur.
- Five load shape scenarios (reference years) based on historical Capacity Years (2016-17 2020-21)
- Model underlying demand and DER, combine to get operational load shape and timing.
- Scale shape and timing to AEMO's operational forecasts





2 Unconstrained Available Capacity

Total generating capacity in hour h, scaled to RCT.

LESS

Total Planned Outages in hour h

Based on participant submitted longduration outages **LESS**

Total Forced Outages in hour h

Simulated based on historical 36 month forced outage rates

Thermal capacity = Capacity Credits assigned

Intermittent capacity based on historical or participant provided profile (for each reference year)

Storage capacity equals storage's max hourly generation capability from 4:30-8:30pm; 0 Otherwise.




Constrained Available Capacity

- CAPSIM optimises the Constrained Available Capacity subject to the following constraints
 - Network constraints must be met
 - Constrained Available Capacity >= hourly Load Forecast (1)
 - Constrained Available Capacity >= Unconstrained Available Capacity (2)
- Stochastic simulation of forced outages and multiple load scenarios means that ~2M+ hourly optimisation solves are required per year
 - Not practicable to solve
 - Optimisation solves are unnecessary in periods where Unserved Energy is unlikely
 - A threshold of 400 MW is used to limit the number of solves



4


Calculate Expected Unserved Energy






Availability Class Requirements (4.5.12)

- Availability Class 1 requirement is minimum level of capacity at which:
 - All Availability Class 2 capacity dispatched to minimise peak demand
 - Outage evaluation criteria satisfied (capacity margin)
 - Planning Criterion satisfied (i.e. EUE < 0.002% of annual expected demand)
- Availability Class 2 capacity is difference between RCT and Availability Class 1 capacity
- Determination of Availability Class 1 capacity also requires simulation of Unserved Energy, but with some differences to the Reliability Assessment approach





Availability Class requirements









QUESTIONS







APPENDIX

Dispatch of Availability Class 2 Capacity



Availability Class Requirements

Dispatch Availability Class 2 (AC2) capacity dispatched to minimise peak demand first. Load forecast is based on average load scenario.

- Assume all ESR will generate in accordance with RCOQ from 4:30-8:30pm (ESROIs)
- Dispatch DSM to minimise the peak of the residual (after ESR is accounted for) load curve
 - Heuristic uses iterative process to dispatch all DSM (subject to constraints on availability) while minimising peak load.
- Final residual load curve is used in simulation of Unserved Energy with AC1 capacity

