


DER Integration

Emerging system security challenges in South Australia

About AEMO



AEMO operates Australia's National Electricity Market and power grid in Australia's eastern and south-eastern seaboard, and the Wholesale Electricity Market and power grid in south-west WA.



Both markets supply more than 220 terawatt hours of electricity each year.



We also operate retail and wholesale gas markets across south-eastern Australia and Victoria's gas pipeline grid.



Collectively NEM & WEM traded over A\$20 billion in the last financial year.



Ownership


40%

Market participants

60%


Governments of Australia

Resource development outlook



National Electricity Market (NEM)


~85% of electrical load
in Australia



South Australia – DER integration

- Within 1-3 years, operational demand in South Australia could become negative.
- When and what operational challenges may arise?
- What actions do we need to take now, to ensure we can operate a secure system?
- Primary focus of DER Program Operations Stream

Minimum operational demand in SA



Agenda

- Preliminary findings and recommended actions



Minimum operational demand thresholds in South Australia

May 2020

Technical Report

Advice prepared for the Government of South Australia



Draft 2020 Power System Frequency Risk Review – Stage 1

Consultation Draft – June 2020

A report for the National Electricity Market

https://aemo.com.au/-/media/files/electricity/nem/planning_and_forecasting/sa_advisory/2020/minimum-operational-demand-thresholds-in-south-australia-review.pdf?la=en

Appendix A, at: https://aemo.com.au/-/media/files/stakeholder_consultation/consultations/nem-consultations/2020/psfrr/psfrr-stage-1.pdf?la=en

Preliminary findings

Challenges identified:

Distributed PV disconnection


Minimum load required to operate under islanded conditions

Under Frequency Load Shedding

Distributed PV disconnection

- Analysis of PV disconnection based upon data from individual inverters
- Verified by bench testing (ARENA project with UNSW)
- Used to calibrate PSS® E model of DER behaviour
- PSS® E studies of a severe but credible fault in the Adelaide metropolitan area:
 - 19 - 20% of underlying load in SA disconnects
 - 38 - 44% of distributed PV generation in SA disconnects


Distributed PV disconnection observed



Distributed PV disconnection

- Severe but credible fault near Adelaide metropolitan area could cause significant disconnection of distributed PV
- Increases largest credible contingency
 - Added to largest generating unit
- Constraint introduced to manage risks of separation/triggering SIPS
- When operating as an SA island:
 - Becomes almost impossible to maintain frequency $>49\text{Hz}$ when DER-load loss exceeds $\sim 150\text{ MW}$ (may be operating in this realm in some periods already)
 - AEMO may no longer have the ability to operate SA in a secure state, if islanding occurs at times of high distributed PV generation

Maximum net PV disconnection (SA)




Measures to manage PV disconnection

1. Improve DER standards (AS4777)
 - <https://sapc.standards.org.au/sapc/public/listOpenCommentingPublication.action>
2. Accelerated voltage ride through test in SA
 - <https://aemo.com.au/en/consultations/current-and-closed-consultations/short-duration-undervoltage-disturbance-ride-through-test-procedure>
3. Improve compliance with standards
4. Collaborate with DNSPs on connection requirements
5. EnergyConnect (new AC interconnector SA-NSW)
6. Network constraints

Minimum demand threshold

- **Islanded operation:** Need adequate load to operate necessary units for system strength, inertia, frequency control and voltage management
- Lowest operational demand experienced: 458 MW (10 Nov 2019)
- 2019 was a “moderate” year – minimum demand can become very low with:
 - Sunny
 - Mild temperatures, on
 - Spring/Summer public holidays

Minimum operational demand in SA




Measures for islanded operation with low load

1. SAPN: Flexible Exports – longer term, sophisticated, supports market integration and distribution management
2. PV shedding – immediate, simple, robust, supports system security
 - Analogous to load shedding
 - Anticipate use only during abnormal conditions, eg. islanding, line outages, etc.
 - Identified options that meet requirements:
 - Enhanced voltage management
 - Smart Meters

Under Frequency Load Shedding

- UFLS designed to arrest severe under-frequency events
 - Separation events
 - Multiple contingency events
- Security challenges identified:
 1. Reducing net load
 2. Reverse flows
 3. Distributed PV disconnection
- Incidence of risk forecast to increase in SA post syncon commissioning
- Actions:
 - Increase UFLS load
 - Dynamic arming of UFLS relays
 - Heywood constraint
 - Protected event submission
 - NER review
- Consultation:

- <https://aemo.com.au/consultations/current-and-closed-consultations/2020-psfr-consultation>



Next steps

- Collaboration with stakeholders on design and implementation of mitigation actions
- Analysis for other NEM regions underway
 1. PV disconnection and impact on contingency sizes
 2. Minimum load required for islanded operation (QLD)
 3. UFLS – data request for NSPs
- Continuing development of tools and data
 - Models in PSSE/PSCAD, rollout for stakeholders
 - Improving data on DER behavior (Solar Analytics, UNSW, ARENA)



AEMO

AUSTRALIAN ENERGY MARKET OPERATOR