

PLANNING METHODOLOGY AND INPUT ASSUMPTIONS

PREPARED BY: Supply Forecasting

VERSION: 1.0

DATE: 30 January 2014

FINAL

Contents

1	Introduction	1
1.1	Data sources and flow	1
2	Scenarios	1
3	Models	2
3.1	Topology	2
3.2	Capacity expansion model	8
3.3	Time-sequential model	9
3.4	Gas modelling	9
3.5	Power system model	10
3.5.1	Demand diversity	10
3.5.2	Response to thermal limitation	11
3.5.3	Wind generation	11
3.5.4	Ratings	11
4	Variables	12
4.1	Demand growth	12
4.1.1	Small-scale generation	13
4.1.2	Rooftop solar photovoltaic uptake	13
4.1.3	Weighting factors	13
4.1.4	Electric vehicles	14
4.2	Emissions reduction policies	14
4.2.1	Renewable energy targets	14
4.2.2	Banking of Renewable Energy Certificates	15
4.2.3	GreenPower	15
4.2.4	Desalination	16
4.2.5	Carbon Price Trajectory	17
4.3	Price elasticity of demand	17
4.3.1	Demand side participation	17
4.4	Minimum reserve levels	17
4.5	Gas prices	18
4.5.1	Gas production cost	18
4.5.2	Gas transport cost	18
4.5.3	Gas volume cost	19
4.6	Coal prices	19
4.7	Renewable resources	19
4.7.1	Wind	19
4.7.2	Insolation	21
4.7.3	Water storages and rainfall	21
4.7.4	Geothermal	21
4.7.5	Biomass	22
4.8	Technological development	22
4.9	Existing production and transmission	22
4.9.1	Electricity generation	22
4.9.2	Gas production	27

4.9.3	Gas reserves	29
4.9.4	Electricity transmission.....	29
4.9.5	Gas transmission.....	31
4.10	New production and transmission.....	31
4.10.1	Committed, advanced, proposed and conceptual.....	31
4.10.2	New production projects.....	32
4.10.3	New transmission projects	33
5	Analysis.....	34
5.1	Market benefits.....	34
5.1.1	Generation capital costs.....	34
5.1.2	Transmission capital costs	34
5.1.3	Operating costs	34
5.1.4	Transmission system losses	34
5.1.5	Changes in involuntary load shedding (reliability benefits)	34
5.1.6	Option value and competition benefits	35
5.2	Financial settings	35
5.2.1	Inflation.....	35
5.2.2	Goods and Services Tax.....	35
5.2.3	Weighted average cost of capital	35
5.2.4	Discount rate	36
5.2.5	Project lifetime.....	36

Version Release History

VERSION	DATE	BY	CHANGES
1.0	30/1/2014	Supply Forecasting	Initial release

1 Introduction

This document provides an overview of the assumptions employed for the Australian Energy Market Operator's (AEMO) planning reports, including:

- The National Transmission Network Development Plan (NTNDP).
- The Electricity Statement of Opportunities (ESOO).
- The Gas Statement of Opportunities (GSOO).
- The South Australian Electricity Report (SAER).

These reports comprise AEMO's long-term view on the evolution of the National Electricity Market (NEM) and the Eastern and South East Australian gas transmission network.

This document describes the classes of data that form the inputs to AEMO's long-term modelling. Actual data is located in referenced documents summarised in Appendix A and accompanying workbooks, available from AEMO's web site.^{1,2} This document supersedes *2013 Planning Consultation Methodology and Input Assumptions* published on 30 January 2013.

AEMO conducts other short- and medium-term planning studies including for the Victorian Transmission Annual Planning Report and to justify network projects in Regulatory Investment Tests for Transmission. These studies use similar assumptions and methodologies to those described in this document. However, given their focus on specific network needs, they use more targeted data assumptions and modelling techniques to the specific areas of investigation. The assumptions and methodologies for those studies are described in their relevant documents.

1.1 Data sources and flow

Assumption data originates from many sources, both externally and as a result of AEMO's activities in the national gas and electricity markets. Two appendices to this document outline where data originates and how data feeds from its origin through AEMO's modelling. *Appendix A - Summary of information sources* presents all data sources and the items taken from each. *Appendix B - Energy Planning Reports: Overview* presents a high level view of how AEMO's national planning documents link together. *Appendix C – Data Flow* presents a series of diagrams with representative process flows that show how data and modelling activities relate to reports.

Different classes of data become available at different times of the year. Each planning report uses the latest data that is available when modelling begins.

2 Scenarios

AEMO's long term planning begins with the development of a series of credible global economic and technological development scenarios.³ These scenarios are designed to cover a wide range of potential future development pathways, and describe the environment in which Australia's energy networks may operate for up to 25 years into the future.

AEMO does not consider any one scenario to be more or less likely than another. Instead, the scenarios are intended to explore the boundary of credible futures, with each scenario based on themes of development such as fast or slow economic growth, high or low technology costs, or relaxed or strict carbon policies.

¹ <http://www.aemo.com.au/Electricity/Resources/Reports-and-Documents/Planning-Reports>.

² <http://www.aemo.com.au/Gas/Planning>.

³ In the context of AEMO planning, a scenario is a self-consistent set of assumptions covering economic and policy settings, estimates of generation technology costs, fuel and carbon cost trajectories, price-demand relationships and other externalities that influence but are not materially affected by the generation expansion plans developed by capacity expansion modelling.


2014 AEMO scenarios have been developed in conjunction with an industry wide Scenarios Working Group (SWG). Representatives were selected to capture generation businesses and network development, large industrial users and emerging technologies.

Detailed descriptions of these scenarios will be published on AEMO website in February 2014.

3 Models

AEMO maintains four mutually-interacting planning models, shown in Figure 1. These models incorporate the assumptions about future development described by the scenarios, and simulate the operation of energy networks to determine a reasonable view as to how those networks grow under different demand, technology, policy and environmental conditions.

Figure 1 - Planning models



3.1 Topology

Each model implements a simplification of the physical energy network, to maintain the size of solutions at reasonable levels while capturing important aspects that materially affect future network development.

The NEM is comprised of five electricity regions, generally (but not exactly) corresponding to the five Commonwealth States of Queensland, New South Wales, Victoria, South Australia and Tasmania, referred to as *regions* and shown in Figure 2⁴. AEMO’s electricity modelling replicates these regions, representing the network as a system of five regional reference nodes connected by inter-regional flow paths. The regional topology allows the model to respond to regional changes in demand, and to optimise regional generation and inter-regional transmission expansion. This arrangement also mirrors the operation of the National Electricity Market Dispatch Engine (NEMDE), which is responsible for directing generation dispatch in the NEM.

⁴ The Australian Capital Territory is included within the New South Wales NEM region.

A regional representation cannot account for differences in energy resources and infrastructure within a region. To incorporate these aspects AEMO's electricity modelling defines sixteen zones, shown in Figure 3, each of which displays a characteristic demand and resource pattern. The South West Queensland (SWQ) zone, for example, has low local demand but sizable solar, coal and gas resources: electricity export is the major challenge in this zone. The neighbouring zone to the east, South East Queensland (SEQ), has high demand, limited access to generation fuels and limits on infrastructure development to maintain the amenity of Brisbane, its suburbs and nearby coastal tourist centres. Energy import is the major challenge in this zone.

Energy resource availability and cost, along with generation build limits are defined according to these zones. Network constraint equations capture transmission limits between zones. Lower-cost zones will receive new generation first, provided that network limits do not unduly constrain that generation. In some cases, the low cost of generation in a particular area will justify both investment in generation infrastructure and investment in transmission infrastructure to supply power elsewhere.

Major gas transmission and production infrastructure is shown in Figure 4. The gas supply-demand outlook model incorporates major gas transmission pipelines, demand centres and production facilities in a representation that closely mirrors the real world, as shown in Figure 5.

Figure 2 – NEM regions




Figure 3 – Electricity planning zones






Figure 4 – Eastern and south-eastern Australian gas production and transmission infrastructure⁵



⁵ AEMO: Figure 6 as published in GSOO 2013 Methodology document. Available at http://www.aemo.com.au/Gas/Planning/~/_media/Files/Other/planning/gsoo/2013/2013%20GSOO%20Methodology.pdf.ashx

Figure 5 - Gas model topology⁶




⁶ AEMO: Figure 5 as published in GSOO 2013 Methodology document. Available at http://www.aemo.com.au/Gas/Planning/~/_media/Files/Other/planning/gsoo/2013/2013%20GSOO%20Methodology.pdf.ashx

3.2 Capacity expansion model

The capacity expansion model is also referred to as the least-cost model. It is used to develop plans for generation and inter-regional transmission expansion suitable to each scenario. It does so by co-optimising electricity generation and inter-regional transmission investment to determine the lowest total generation and transmission cost, including both capital expenditure and operating costs. The model is rich in options for the location of new generation (by Electricity Planning Zone), the technology employed by new generation, generation that may retire and projects that increase transmission capability⁷.

Limits to computing resources mean that the capacity expansion model cannot consider every combination of every option for every time period in every scenario over a modelling horizon that may extend up to 25 years. The capacity expansion model reduces problem complexity by reducing the number of instants of time it considers. To ensure that this reduction is representative of the total period of time in the modelled horizon, the load duration curve is partitioned into blocks, similar to those shown in Figure 6⁸.

Figure 6 – A load duration curve partitioned into five load blocks



Blocks are generated from the load duration curves of each region in each month in each modelled year. The monthly partitioning captures seasonal variation while the yearly partitioning captures growth in demand. To ensure supply capacity adequacy, 10% probability of exceedence (POE) demand curves are used. The demand curves used work in concert with the reserve margins applied to modelling. That is, the reserve margins used are specified with reference to 10% POE demand. Other demand curves may be used (such as 50% POE or 90% POE), however these would require their own larger reserve margins to be defined. The capacity requirement that is driven by the combination of demand and reserve margins is the same in each case.

Other time-varying data (for example, assumed output of wind generators) is similarly treated in the capacity expansion model. Further detailed technical discussion of the capacity expansion model is available as part of 2013 Planning Assumptions website.⁹

⁷ http://www.aemo.com.au/Consultations/National-Electricity-Market/~media/Files/Other/planning/2013Consultation/Planning_Studies_2013_Additional_Modelling_Data.ashx

⁸ AEMO uses between 12 and 20 blocks to approximate a load duration curve, depending on the requirements of the simulation.

⁹ <http://www.aemo.com.au/Electricity/Planning/Related-Information/~media/Files/Other/planning/Capacity%20expansion%20modelling.ashx>

The capacity expansion model is implemented using the PLEXOS for Power Systems software from Energy Exemplar. The 2013 PLEXOS model is available as part of 2013 NTNDP publication.¹⁰

3.3 Time-sequential model

The capacity expansion model, while considering a large number of options, produces relatively coarse estimates of generation, flow and price that may be used to assess market benefits or report on network performance. The generation and transmission expansion plan developed by the capacity expansion model is validated using a time-sequential model that mimics the dispatch process used by NEMDE.

The time-sequential does not perform decision-making about new investment, but does consider the modelled time horizon at much higher resolution compared to the capacity expansion model. The time-sequential model performs optimised electricity dispatch for every hour in the modelled horizon, allowing the development of metrics of performance of generation (by location, technology, fuel type or other aggregation) and transmission (flow, binding constraint equations).

The high time resolution allows this model to capture the effects of inter-regional demand diversity and diversity between intermittent supply and demand.

This model can also represent unplanned generation plant outages and other uncertain variables providing insight into the reliability of the power system under a range of potential operating conditions.

The time-sequential model is used in a range of planning studies:

- Hourly gas-powered generation produced by the time-sequential model is used as an input to GSOO gas modelling
- The NTNDP: the time-sequential model validates results from the capacity expansion model and provides conditions for power system modelling (see Section 3.5)
- Power system reliability assessments: assessing power system reliability and identifying the amount of generation reserves required to achieve a required level of reliability requires modelling the power system under planned and unplanned generation outage conditions
- Market benefit assessments: modelling hourly dispatch and outage conditions provides relatively accurate assessments of the market benefits of specific augmentations.

The time-sequential model is implemented using the Prophet software from Intelligent Energy Systems. The model was published with the ESOO in 2013¹¹.

Based on stakeholder feedback on AEMO's methodology and assumptions for least cost modelling and generator retirements in developing generator expansion plans, AEMO intends to form a small focus group to review the methodology and consider potential options for improvement. AEMO invites nominations from stakeholders with relevant market modelling capabilities to participate in the focus group.

The outcomes of the review and potential improvements to the model will be published on AEMO website.

3.4 Gas modelling

The gas supply-demand outlook model (represented as 'Gas Modelling' in Figure 1) assesses reserves, production and transmission capacity adequacy for the Gas Statement of Opportunities (GSOO). The model performs gas network production and transmission optimisation at daily time intervals that minimises the total cost of production and transmission, subject to capacity constraints, according to the simplified network topology shown in Figure 5.

There is a feedback loop between the GSOO gas modelling and NTNDP electricity modelling to co-optimize electricity and gas transmission augmentations with generation expansion, improving the quality of generation expansion plans and GPG demand forecasts.

¹⁰ <http://www.aemo.com.au/Electricity/Planning/National-Transmission-Network-Development-Plan>

¹¹ http://www.aemo.com.au/Electricity/Planning/~/_media/Files/Other/planning/esoo/2013/2013_ESOO_prophet_database.zip.ashx

Assessment of reserves requires the gas supply-demand outlook model to consider the difference between production and transmission solutions to supply shortfall: an augmentation of production near supply shortfall may draw on a different reserve to a transmission augmentation solution, leading to different reserve depletion projections. For example, supply shortfall in Melbourne may be addressed by increasing production from the Gippsland Basin, increasing production from the Otway Basin, or increasing transmission capacity between the Moomba-Sydney Pipeline and Melbourne, which will ultimately source gas from north-eastern South Australia or Queensland.

The gas supply-demand outlook model does not contain cost-related information in sufficient detail to form a reliable view on transmission and production augmentation based on cost efficiency. Instead, AEMO reviews and models publicly-announced and generic augmentation projects and uses model outcomes to aid assessment of reserves adequacy.

The gas supply-demand outlook model is implemented using a combination of the General Algebraic Modelling System (GAMS), SQL Server database and a browser interface. The Gas model is available on AEMO website as part of 2013 GSOO publication¹².

3.5 Power system model

The power system model contains a highly detailed representation of the physical transmission network underlying the NEM, including individual generating units, transmission lines, transformers, switching elements, reactive power management elements and loads represented at transmission connection points. All major transmission elements in the NEM are represented. In most cases, major transmission elements are those that operate at 220 kV and above, however there are some radial elements operating at 220 kV that are not represented, and there are some elements operating at lower voltages that are represented because they perform transmission functions.

The model is used to assess intra-regional transmission system adequacy under a range of conditions¹³. Different types of planning studies require a different level of detail in the network representation as well as the adequacy assessment. For example, long-term planning studies such as the NTNDP are more exploratory in nature and require a higher level network representation than a study into the local needs of a specific area.

These sections describe the model and the approach taken in long-term planning studies. More targeted studies will be described in their relevant publications.

In performing long-term planning adequacy assessments, AEMO takes guidance from the planning criteria outlined in the National Electricity Rules (Section S5.1.2.1), and any criteria defined at state level that may be relevant to national planning.

The assessment is performed by undertaking load flow analysis, which calculates the instantaneous flow of power between locations where energy is generated and where it is used. This modelling validates the expansion outcomes of the capacity expansion model and the dispatch outcomes of the time-sequential model by confirming that the power system continues to operate in a secure and reliable manner as demand grows and the generation mix changes. Reliability is assessed by monitoring the loading on the transmission network when the power system is operating with all equipment in service (system intact) and also under a potential unplanned outage of a transmission network element or generating unit. The assessment considers the capability of the transmission system for transfer of energy, and identifies thermal limitations¹⁴ that may be constraining power flow.

3.5.1 Demand diversity

To date long-term planning studies (such as the NTNDP) have assessed network adequacy using the 10% POE maximum demand forecasts developed for the National Electricity Forecasting Report. Each point of

¹² <http://www.aemo.com.au/Gas/Planning/Gas-Statement-of-Opportunities/GSOO-2013-Supply-Demand-Modelling-files>

¹³ The capacity expansion model contains options to augment inter-regional transfer capabilities but its regional representation prevents consideration of intra-regional limitations.

¹⁴ Thermal limitations arise due to the resistance of transmission lines to the flow of electrical current. When energy flows, transmission lines heat up and begin to sag. Transmission lines may be damaged if allowed to become too hot for too long and if allowed to sag, they could breach minimum safety clearances. Thermal limitations constrain the flow of current to prevent unsafe operation or potentially damaging heating of the conductors.

connection is represented with the load coincident with the time where the NEM region is at its maximum demand level. In this sense, the power system studies account for demand diversity within a NEM region. NTNDPs to date have not assessed local transmission network adequacy to meet localised peak demand at times outside of the 10% POE regional maximum demand.

Generation dispatch patterns and inter-regional power transfer at the time of regional maximum demand are taken from the time-sequential model results where these have been calculated or from capacity expansion model results otherwise.

3.5.2 Response to thermal limitation

The primary result of the load flow analysis is a list of the transmission system elements that may be overloaded during times of high demand under the projected conditions of demand and generation and transmission expansion.

When the power system model identifies thermal overload on monitored power system elements, AEMO addresses the overload using a series of techniques that attempt to minimise costs:

1. Re-dispatch generation – more expensive generation closer to the load is dispatched in preference to the generation that was dispatched by the time-sequential model.
2. If simple re-dispatch cannot address the overload, relocate new generation to an alternative connection point in the same planning zone.
3. If relocation of generation in the same zone cannot address the overload, relocate new generation to an adjacent zone.
4. If relocation and re-dispatch of generation cannot address the overload, choose an appropriate intra-regional transmission system augmentation to address the overload directly. This may be an option presented by jurisdictional planning bodies in their annual planning reports or an option developed by AEMO.
5. If intra-regional transmission augmentation is required and the cost of identified augmentations is considered material to the capacity expansion outcomes, the augmentation cost is added to the costs of new generation considered by the capacity expansion model, in the zone where the augmentation is required. The capacity expansion model is re-solved, which may result in the relocation of generation, different transmission system augmentations being chosen, a combination of both, or no change to the expansion plan.

The expansion plan is considered stable when no further locations of transmission overload are identified.

3.5.3 Wind generation

AEMO develops wind contribution factors that specify the amount of wind generation that can be relied upon during times of maximum demand¹⁵. These wind contribution factors are used by both the capacity expansion model and the power system model, while the time-sequential model uses an hourly wind generation profile obtained from historical observations.

High demand and low wind generation output constitute a particular set of conditions that may result in overload of transmission elements. Another important set of conditions occurs when demand is low and wind generation is high. Because wind energy is low cost, such times can impart a high value to transmission augmentation. To identify network congestion at times of high wind generation, additional studies with wind generation set at 80% of installed capacity and moderate demand are also performed.

3.5.4 Ratings

Ratings on modelled transmission elements change according to the instant of time considered in each model solution. In summer, transmission element capability ratings are generally lower because higher ambient temperatures make it more difficult for those elements to dissipate heat.

¹⁵ Contribution Factors tab in the workbook at http://www.aemo.com.au/Consultations/National-Electricity-Market/~media/Files/Other/planning/2013Consultation/Planning_Studies_2013_New_Generation_Technical_Data.ashx

In general, AEMO considers maximum demand in summer, because demand is highest at the time and ratings are low. On some occasions AEMO will also consider winter maximum demand. Tasmania, for example, typically experiences maximum demand in winter. In 2012, maximum demand in New South Wales occurred in winter, but was similar in magnitude to summer maximum demand. In that case, AEMO considered both summer and winter maximum demand.

AEMO uses continuous ratings for pre-contingency load flow analysis.

Transmission elements may be operated above their continuous ratings for short periods of time. These short term ratings are used for contingency load flow analysis, as contingencies are expected to be cleared relatively quickly by power system operators.

4 Variables

4.1 Demand growth

Change in demand for electricity and gas is a key driver of the evolution of energy production and transmission systems. Demand can change in two ways:

- The amount of energy that must be provided over the course of time.
- The amount of power that must be provided instantaneously.

For electricity, these are referred to as *energy* and *maximum demand* (MD) respectively, and are measured in megawatt-hours (MWh, energy) or megawatts (MW, power). For gas, where instantaneous demand has a lesser impact on supply, the concept of instantaneous power is less relevant and gas demand is often expressed in terms of a specific timeframe: maximum hourly quantity (MHQ), maximum daily quantity (MDQ) or annual quantity. All are measured in gigajoules (GJ), terajoules (TJ) or petajoules (PJ) depending on the length of time under consideration.

AEMO uses scenario descriptions to develop regional electricity and gas demand projections to suit long term planning timeframes. The *National Electricity Forecasting Report*¹⁶ is published by AEMO mid-year, and presents 10% and 50% POE MD and energy projections for each NEM region up to twenty years into the future. These projections are extended to a twenty five year range for use in the NTNDP.¹⁷ The 50% POE projections reflect an expectation of typical MD conditions. The 10% POE projections reflect an expectation of extreme MD conditions. Projected energy is the same in each case.

In electricity modelling, the energy and MD projections in each region are combined with a typical hourly demand profile for that region, using a time series from a reference historical financial year, to produce hourly demand profiles that cover the full modelling period. When investigation into the sensitivity of outcomes to demand diversity is required, other reference years may be used as the basis for future demand profiles.

Energy and MD projections published in the NEFR incorporate some generation that is explicitly modelled in the capacity expansion and time-sequential models. When developing demand profiles, the projections must be adjusted to avoid double counting. A detailed description of demand profile development is given in *Demand Trace Development*, available from the Planning Assumptions web page.¹⁸

Gas demand forecasts are produced by combining data from four sources: mass market (residential and commercial) customers, large industrial facilities, gas powered generation and LNG export facilities. Mass market and large industrial demand is developed by AEMO each year and published in the GSOO. Detailed descriptions of modifications to demand from gas powered generation and LNG export are presented in GSOO methodology document.¹⁹

These data will be reviewed in 2014 following the publication of new scenarios.

¹⁶ Available from <http://www.aemo.com.au/electricity/planning/forecasting>

¹⁷ The average growth in demand over the final ten years of the NEFR projections is used to extend the NTNDP projections to a twenty-five year horizon.

¹⁸ <http://www.aemo.com.au/Electricity/Planning/Related-Information/2014-Planning-Assumptions>

¹⁹ http://www.aemo.com.au/Gas/Planning/~/_media/Files/Other/planning/gsoo/2013/2013%20GSOO%20Methodology.pdf.ashx

4.1.1 Small-scale generation

Demand projections are developed based on the demand that appears on the transmission system. Non-significant non-scheduled generators that are connected to a distribution network appear to the transmission system as a reduction in demand from that distribution network. The market model includes representations of scheduled, semi-scheduled and significant non-scheduled generators. Non-significant non-scheduled generators, which are not represented in the market model, are incorporated into the energy and MD projections.

The 2012 National Electricity Forecasting Report (NEFR) tables the non-scheduled generators that are incorporated into energy and MD projections (those that are used in annual energy forecasts and *not* part of operational demand).²⁰

4.1.2 Rooftop solar photovoltaic uptake

An analysis of the uptake of rooftop solar photovoltaic (PV) generation was undertaken by AEMO in 2012, published as the Rooftop PV Information Paper²¹. The outcomes of that analysis will be used as the basis of rooftop PV modelling in 2014.

Rooftop PV modifies the shape of the demand curve, as a larger portion of demand is removed from sunny times of the day as the amount of installed rooftop PV increases. The uptake of rooftop PV is also projected to occur at a different rate than the change in underlying demand.

Rooftop PV is treated in the market models similarly to non-significant non-scheduled generation. That is, there is no explicit representation of rooftop PV in the model, rather, the expected generation from rooftop PV is subtracted from the demand profile.

To accommodate modification to the demand profile and different rates of demand growth and rooftop PV uptake, the reference demand curves are adjusted to remove the effect of rooftop PV prior to growing future demand profiles. Rooftop PV generation profiles are developed independently, taking changes in uptake into account. This generation is subtracted from the PV-adjusted demand curves to produce a demand curve that incorporates both growing demand and increasing uptake of rooftop PV.

4.1.3 Weighting factors

In time-sequential dispatch modelling, both the 10% POE and 50% POE demand conditions are used to contribute to reported generation and transmission network performance metrics. Outcomes from two simulations are combined to produce a single-figure result.

When it is assumed that demand follows a normal distribution, and that 50% POE results have broadly similar outcomes to 90% POE outcomes, the weighting factors are 30.4% on 10% POE outcomes and 69.6% on 50% POE outcomes.

Figure 7 shows the probability density function of the load duration curve in Figure 6, together with a normal distribution developed using the demand data's mean and standard deviation. The data does not conform exactly to a normal distribution curve, and weighting factors may be made more appropriate by considering an alternative distribution assumption. AEMO is investigating whether the shape of demand probability densities materially affect the weighting factors used to determine simulation results.


Preliminary investigation has shown that introducing a 5% POE profile to the weightings can improve the accuracy of the weighted results, particularly when considering unserved energy outcomes. The most appropriate weighting factors under this arrangement are approximately 7% on 5% POE outcomes, 23% on 10% POE outcomes, and 70% on 50% POE outcomes.

AEMO is reviewing its ability to apply this approach more broadly to other time-sequential modelling studies.

²⁰ 2012 National Electricity Forecasting Report, Appendix C. Available from: <http://www.aemo.com.au/Electricity/Planning/Forecasting>.

²¹ Rooftop PV Information Paper. Available from <http://www.aemo.com.au/Electricity/Planning/Forecasting/Information-Papers-2012>.

Figure 7 – Probability density of the load duration curve in Figure 6



4.1.4 Electric vehicles

Electric vehicles are expected to become a significant new source of electricity demand within the typical timeframes of AEMO's long term planning.

Electric vehicle demand is incorporated into the models by developing a daily charging profile consistent with charging behaviour assumptions, growing the profile to accommodate growth in demand due to increased uptake, and adding the resulting profiles to the projected regional demand profiles in each scenario. Unlike rooftop photovoltaic generation, there is presently no significant penetration of electric vehicles in any NEM region, and reference year demand profiles are assumed not to contain time of day distortions due to electric vehicle load. In this case, reference year historical demand profiles are not adjusted prior to application of projected future electric vehicle charging load profiles.

4.2 Emissions reduction policies

4.2.1 Renewable energy targets

The Australian Government sets targets for energy generated by renewable sources through the Large-scale Renewable Energy Target (LRET) and the Small-scale Renewable Energy Scheme (SRES). These targets are encouraged by requiring wholesale purchasers of electricity to purchase Renewable Energy Certificates (RECs) which, from 1 January 2011, are classified as either Large-scale Generation Certificates (LGCs) or Small-scale Technology Certificates (STCs) for the purposes of meeting the LRET and the SRES respectively.²²


In the capacity expansion model, the LRET is enforced by setting an annual energy target that must be met by renewable generation. To incorporate the LRET into the capacity expansion model, two adjustments are made to the published LRET figures:

- The number of LGCs that are required to meet the target is scaled by an amount that reflects the energy generated in the NEM compared to the amount of energy generated Australia-wide.

²² Australian Government. *Fact Sheet: Enhanced Renewable Energy Target*. Available from: <http://www.climatechange.gov.au/government/initiatives/renewable-target/fs-enhanced-ret.aspx>.

- The calendar-year targets defined by the LRET are converted to financial year targets by averaging the targets in adjacent calendar years.

LRET targets will be published in the *2014 additional modelling data workbook*.



The majority of STCs are generated by domestic rooftop solar installations. The uptake of rooftop solar power is modelled as part of the demand projections (see Section 4.1.2), so no explicit representation of STCs is included in any of the models.

4.2.2 Banking of Renewable Energy Certificates

The 2012 ESOO highlighted an existing surplus of large-scale generation certificates (LGCs) in renewable energy certificate markets, driven by a faster-than-expected growth in renewable generation and contracting demand. A surplus of certificates can defer renewable generation investment, and may need to be considered for electricity capacity expansion modelling.

AEMO is investigating the value of incorporating certificate banking into capacity expansion modelling.


4.2.3 GreenPower

GreenPower is a federal government program to empower consumers to purchase electricity from renewable sources. Sales of GreenPower electricity represent an additional requirement for renewable generation over and above the targets imposed by the LRET and the SRES. The capacity expansion and time-sequential models use renewable generation targets that are adjusted to include GreenPower sales.

AEMO’s modelling scenarios define three GreenPower sales trajectories: rising, falling and flat. These trajectories are shown with historical sales in Figure 8, where the low trajectory incorporates contraction of sales by 2% per year, and the high trajectory incorporates expansion of sales by 4.7% per year. GreenPower sales trajectory data is available in the *2013 additional modelling data workbook*²³.

²³ See note 18.

Figure 8 – GreenPower sales trajectories



4.2.4 Desalination

Power for desalination plants can represent a significant component of demand. Additionally, all major desalination plants in Australia are committed to purchasing renewable energy over and above the requirements of the LRET.

In 2012, desalination load was added to the LRET. The end of drought conditions in eastern Australia has resulted in all major desalination plants being placed in standby mode. LGC purchase agreements for desalination plants usually apply in the long term, and are not affected by the plants' operational status. It is assumed that LGCs purchased under such agreements will be re-sold, however, so demand for LGCs from desalination plants do not add to the LRET when plant are non-operational.

In 2014, demand for LGCs from desalination plants is assumed to be zero.

Table 2 outlines the major desalination plants in eastern Australia, their maximum water output and power and energy consumption at maximum output when operational.

Table 1 – Major desalination plants in the NEM

Plant	Region	Production (GL/year)	Power consumption (MW)	Energy consumption (GWh/year)
Tugun	Qld	45	17	150.5
Kurnell	NSW	91	48	420
Port Stanvac	SA	100	57	500
Wonthaggi	Vic	150	98	860

4.2.5 Carbon Price Trajectory

Carbon price trajectories to be used in 2014 planning studies will be updated following the completion of scenarios definition work in early 2014. The price trajectories will be published as part of additional modelling information²⁴.

4.3 Price elasticity of demand

The energy and MD projections incorporate the response of consumers to electricity prices, based on the price outcomes of the reference year (that is, the prices that were reported in the reference year already incorporate consumers' response to price, because demand and prices would have been higher were there no consumer response present). Consumer response to price modifies the shape of the demand curve, which is strongly correlated with price. This shape is maintained by the market model, even as energy and MD projections change on a year by year and scenario by scenario basis. It is assumed that the modelled price outcomes will continue to be correlated to demand, and as such no further consumer price elasticity to demand is modelled.

4.3.1 Demand side participation

Further to the price elasticity of demand present in projections of energy and MD is the concept of demand-side participation (DSP). DSP is an agreed, additional change in demand beyond price elasticity that can occur when the power system becomes stressed. It is often provided by industrial customers that have interruptible loads.

The capacity expansion and time-sequential models incorporate DSP by reducing the generation required when modelled prices reach specific levels²⁵. Absolute amounts of available DSP (in MW, in each region) depend on scenario, and are listed in the *2013 additional modelling data*²⁶ workbook. These amounts are activated in three price bands:

- 30% at \$1,000/MWh.
- 30% at \$3,000/MWh.
- 40% at \$5,000/MWh.

That is, demand will be reduced by 30% of available DSP when the modelled price reaches \$1,000/MWh. DSP is assumed to be available in all trading intervals and 100% reliable.

4.4 Minimum reserve levels

The capacity expansion model and the electricity supply-demand calculator both contain a representation of minimum reserve levels. Minimum reserve levels represent a safety margin of spare capacity that must be maintained at all times to ensure the power system operates within long-term reliability standards.

²⁴ See note 18.

²⁵ Very high prices are assumed to indicate times when reserves of available power in a region are approaching their limit.

²⁶ See note 18.

In the capacity expansion model, minimum reserve levels adjust the amount of generation that must be available in each region relative to the value of peak demand. The capacity expansion model brings new generation online when the sum of the maximum demand and the minimum reserve level exceeds the available generation²⁷.

In the electricity supply-demand calculator, minimum reserve levels are used in conjunction with peak demand to determine low reserve condition (LRC) points. AEMO is currently reviewing the methodology used to both calculate reserve requirements and assess supply adequacy. This review aims to identify accuracy and efficiency gains that may be possible by moving away from pre-calculated minimum reserve levels and the supply-demand calculator approach, in favour of using the same time-sequential model that AEMO employs for detailed market benefit assessments.

The time-sequential model performs a probabilistic sampling of generator outages, so an assessment of system reliability is a direct output of the model, without the need for an intermediate set of minimum reserve levels.

This approach increases quality, efficiency, and transparency in the ESOO's supply adequacy assessment.

4.5 Gas prices

Gas costs fall into a number of categories:

- Gas production cost: the cost incurred to bring gas out of reserves and treat it to a specification suitable for transport.
- Gas transport cost: the cost incurred to compress and move gas from the place of production to the place of consumption.
- Gas volume cost: the premium paid by consumers based on the volume of gas consumed, with higher volumes incurring lower premiums.

The sum of these costs represents the gas price paid by consumers.

AEMO plans to engage external consultants to review the fuel and technology cost data for use in 2014 Planning Studies. The consultant report and the revised set of data will be published on Planning Assumptions²⁸ website by June 2014.

4.5.1 Gas production cost

As part of the 2012 GSOO, AEMO undertook consultation to describe gas production costs in eastern and south eastern Australia. The consultation, by CORE Energy Group, was published in August 2012²⁹, and includes estimates of the cost to produce at existing facilities and new facilities based on expected return from announced capital investments.

AEMO is reviewing the need to update this data in 2014.

4.5.2 Gas transport cost

As part of the 2012 GSOO, AEMO undertook consultation to describe gas transport costs in eastern and south eastern Australia. The consultation, by CORE Energy Group, was published in June 2012³⁰, and includes estimates of the cost to transport gas in existing pipelines and the cost to construct new pipelines based on the expected return from announced capital investments.

AEMO is reviewing the need to update this data in 2014.

²⁷ Reserve can be shared between regions, so a transmission project may be used to supply reserve available in a neighbouring region, instead of establishing new generation in the region experiencing shortfall.

²⁸ See note 18.

²⁹ Available at <http://www.aemo.com.au/Gas/Planning/Gas-Statement-of-Opportunities/Production-Costs>.

³⁰ Available at <http://www.aemo.com.au/Gas/Planning/Gas-Statement-of-Opportunities/Transmission-Costs>.

4.5.3 Gas volume cost

Gas-fired power stations are end-consumers of gas, and the fuel costs they incur are a key input to the electricity capacity expansion model. In general, the cost of fuel to a power station is composed of a production cost, a transport cost and a volume cost, where the volume cost reflects market conditions. Gas-fired power stations with low power output or low capacity factor incur higher volume costs than higher-power, higher capacity factor plant.

In the capacity expansion and time-sequential models, open-cycle gas turbine (OCGT) generators are assumed to operate at a lower capacity factor and at lower power output compared to combined-cycle gas turbine (CCGT) generators. OCGT generators subsequently pay higher volume costs compared to CCGT generators.

Gas production and transport costs developed by CORE Energy Group use a bottom-up, cost-of-development approach, whereas the wholesale fuel cost projections developed by ACIL Tasman use international pricing signals as the basis for determination of domestic prices for wholesale consumers.³¹ The difference between these two constitutes the gas volume cost. Gas-fired power stations will pay the wholesale price as projected by ACIL Tasman in the electricity capacity expansion and time-sequential modelling.³²

4.6 Coal prices

Current prices for black and brown coal were estimated by ACIL Tasman for the 2012 NTNDP.

Coal price projections will be updated in 2014 as part of the fuel and technology cost review and published on Planning Assumptions website³³.

4.7 Renewable resources

4.7.1 Wind

In 2009 the Inter-Regional Planning Committee developed the concept of a wind bubble to model the wind resource available to the NEM. A wind bubble defines a geographical area where wind speeds are considered sufficient to be attractive for new wind development.

Modelled wind bubbles are shown in Figure 9.

For each wind bubble, a typical hourly wind speed profile is developed that covers a single trading year, based on proprietary data provided by the Commonwealth Scientific and Industrial Research Organisation (CSIRO). The wind speed profile is re-applied without modification in each modelled year.

Wind speed profiles are converted to normalised³⁴ wind turbine power output profiles based on a generic turbine power conversion curve. New wind generation generates according to a combination of the normalised power output profile and its modelled capacity.³⁵

For existing semi-scheduled wind generation, power output is available in AEMO's Market Management Systems (MMS) database, from which a single typical year³⁶ is used to determine a power output profile for modelling. The power output of small, non-scheduled wind generation is included in the demand profiles as a reduction in demand.

³¹ This approach implicitly assumes that domestic prices are directly affected by international prices. This assumption is compatible with the position of eastern Australian gas markets once LNG export facilities are established.

³² Available at http://www.aemo.com.au/Electricity/Planning/National-Transmission-Network-Development-Plan/-/media/Files/Other/planning/ACIL_Tasman_Fuel_Cost_%20Projections_2012.ashx.


³³ See note 18.

³⁴ Where the maximum output is 1, and the minimum output is 0.

³⁵ Subject to network constraints.

³⁶ The 'typical year' is the same as the reference year for demand profiles.

Figure 9 – Wind bubbles



4.7.1.1 Contribution of wind to peak demand

Wind generation forecasts available for dispatch are not available over the long term. Without certainty about the power output of wind generators at times of high demand, models that do not implement generation profiles (such as the capacity expansion model and the electricity supply-demand calculator) cannot determine whether wind generators are contributing a large or small amount of capacity to meet that demand.

To manage the uncertainty of wind generation supply during times of high demand, AEMO studies the historical correlation between wind generation and high demand, and determines an average regional contribution to peak demand that can be used for capacity expansion planning. For example, in Victoria the long-term average availability of wind generation during summer peak demand is approximately 6.5% of the total installed wind capacity in that region. During winter peak demand, approximately 7.2% of total installed wind generation is available to meet demand, on average.

The capacity expansion model and electricity supply-demand calculator use these values to determine what portion of total installed wind capacity is available to meet peak demand, informing decision-making about when to establish new generation or when LRC points occur, respectively.

The contribution of wind to peak demand was most-recently reported as part of the NEM Historical Information Report³⁷ in 2013. This data will be updated in 2014.

4.7.2 Insolation

The capacity expansion and time-sequential models each contain a representation of large-scale solar power stations so that they may be considered for future generation expansion.³⁸ Estimation of the moment to moment power availability of solar power stations requires knowledge about the solar resource.

In the short term, the presence of clouds or aerosols in the atmosphere can make the solar resource highly variable and uncertain. Over the long term, information about the typical behaviour of weather systems in an area provides a reasonably accurate view of future solar energy availability.

Improvements to modelling of the solar resource were introduced in 2012, as a consequence of work undertaken for the 100% Renewable Energy Study currently being undertaken for the Department of Climate Change and Energy Efficiency. A detailed report and datasets are available from the input assumptions web page for that study.³⁹ AEMO will use the solar profiles developed for the 100% Renewable Energy Study in 2014.

4.7.3 Water storages and rainfall

The NEM contains scheduled hydroelectric generators in Tasmania, Victoria, New South Wales and Queensland, most of which are represented explicitly in the time-sequential model, along with their associated reservoirs and water inflows. For each reservoir, the capacity, initial levels and the expected inflows from rainfall all determine the availability of energy for hydroelectric generation.

The time-sequential model will incorporate the latest available storage capacity and water level information at the time of modelling, using values provided by hydroelectric generators.⁴⁰

Inflows to hydroelectric generation storage reservoirs are based on long-term rainfall statistics. AEMO will be updating the data in 2014.

4.7.4 Geothermal

The capacity expansion and time-sequential models each contain a representation of large-scale geothermal power stations so that they may be considered for future generation expansion.

³⁷ http://www.aemo.com.au/Electricity/Planning/~/_media/Files/Other/planning/NEM_Historical_Information_Report_2012_13.aspx

³⁸ Australia's first large-scale solar power stations are expected to be commissioned in 2015 or 2016 (Source: AGL – see http://agk.com.au/brokenhill/).

³⁹ Available at <http://www.climatechange.gov.au/government/initiatives/aemo-100-per-cent-renewables/aemo-input-assumptions.aspx>.

⁴⁰ For Snowy Hydro: <http://www.snowyhydro.com.au/water/lake-levels-calculator/>. For Hydro Tasmania: <http://www.hydro.com.au/water/energy-data>. For Victoria: <http://www.g-mwater.com.au/water-resources/storages>. For Queensland: <http://www.stanwell.com/hydro.aspx>.

Geothermal generation is not energy-limited like wind and solar generation, so a detailed view of energy availability is not required in this case. The geothermal resource is limited, however, to specific places where subsurface heat is of a quality required for power generation. The capacity expansion model limits the zones in which geothermal generation can be established to NQ, CQ, SWQ, NCEN, MEL, LV and NSA. The time-sequential model assumes that the geothermal resource is not depleted within the timeframes covered by any model (coal and gas is treated in the same way).

Geothermal generators do not incur any fuel costs in their operation, but have much higher than normal auxiliary loads compared to conventional thermal power stations due to the requirement for pumping a working fluid long distances.

4.7.5 Biomass

In the context of AEMO's planning, biomass is waste vegetation that may be burned in thermal generators.⁴¹ There are two major sources of biomass in Australia. In Queensland and New South Wales, sugar cane crops generate significant biomass at times of harvest.⁴² In Victoria, South Australia and Tasmania, biomass is currently sourced from landfill sites, sewerage treatment plants and some specialty operations such as paper mills and is available all year round.

All existing biomass generators in the NEM are non-scheduled, and are not explicitly modelled. Biomass generators established as part of future generation expansion plans are assumed to have fuel available all year round.

Biomass for generation is assumed to be a waste product, and power generation facilities are assumed to be co-located with processing facilities, resulting in the cost of fuel for biomass generators being very low. Fuel costs for biomass generation will be revised as part of the fuel and technology cost review in 2014.

4.8 Technological development

The capacity expansion model develops plans for new generation and transmission investment. In a forward view of generation investment over the modelled timeframes, technological advances can have a significant impact on new generation investment. Such advances may include increased efficiency of existing processes, the emergence of entirely new technologies or pre-commercial technologies, or reducing costs due to scales of economy and manufacturing learning.

In 2014 AEMO will engage consultants to develop technology availability and cost data, based on the guidance of the scenario drivers as established by the scenarios working group. The revised data will be used in 2014.

4.9 Existing production and transmission

4.9.1 Electricity generation

4.9.1.1 Capacities

Seasonal availability of modelled generators will be sourced from AEMO's Generator Information Page⁴³, using the latest information available when modelling begins.

4.9.1.2 Ramp rates

All rotating machinery develops inertia during operation, depending on the mass of the rotating equipment. Time is required to change rotation from a state of rest to operational speeds or from operational speed to rest. Additionally, thermal equipment develops heat inertia associated with the heating and cooling of components or working fluids. The rate at which a generating unit can increase or decrease its power output in response to ambient conditions or dispatch commands is referred to as its ramp rate.

⁴¹ AEMO does not model biomass used for heat generation which in turn may offset electricity demand for heating.

⁴² In New South Wales, the cane harvest is undertaken from late July to early November. In Queensland, the harvest is undertaken from late May to mid-November.

⁴³ Available at <http://www.aemo.com.au/Electricity/Planning/Related-Information/Generation-Information>.

The time-sequential model contains a representation of the ramp rate of generating units. Other models cannot use ramp rates because they do not treat time continuously.

Ramp rates for modelled generators are contained in the *Planning Assumptions existing generation data* workbook⁴⁴.

4.9.1.3 Generator auxiliary load

The capacity expansion and time-sequential models contain representations of the auxiliary load developed by generating units during operation.

Generating units typically consume a material proportion of their output during operation. Major components of auxiliary load include water pumping, pollution control systems, flue gas handling and fuel handling, with different technologies developing different auxiliary load profiles. In the models, auxiliary load is expressed as a percentage of total output.

Regional average auxiliary loads are reported as part of the *National Electricity Forecasting Report*. Auxiliary loads for existing generators and each class of new generator are reported as part of the *Cost of Construction New Generation Technology* report.

4.9.1.4 Fixed and variable operating costs

The capacity expansion and time-sequential models contain representations of the fixed and variable operating costs of all existing generating units and all classes of new generating units.

Fixed operating costs are incurred by generating units that are available for dispatch, regardless of whether they are or are not dispatched in any modelled trading interval. They reflect components of cost such as retention of staff and maintenance of buildings – any cost that is incurred in keeping a power station ready to generate. Units that retire do not incur fixed operating costs after their retirement.

Variable operating costs are incurred by generating units whenever their output is non-zero. They reflect “use” of the generating units such as costs incurred for equipment maintenance, having staff on-shift and consumable items such as lubricating oil. They do not include fuel or emissions costs, which are modelled separately.

4.9.1.5 Emission factors

Under the Clean Energy Legislative Package⁴⁵, generating units that emit atmospheric pollutants are required to purchase carbon permits for every tonne of carbon dioxide-equivalent emissions. The capacity expansion and time-sequential models calculate power output for each generating unit over their defined time horizons, and a carbon emission intensity factor is used to calculate the amount of emissions that are produced so that the cost of complying with emissions reduction legislation can be determined.

Previously, emissions factors (for existing generators) were determined in consultation with ACIL Tasman, last reported in *Fuel resource, new entry and generation costs in the NEM 2009*.

Under the *National Greenhouse and Energy Reporting Act 2007* (NGER) generators are required to report their emissions to the Clean Energy Regulator (CER) for the purposes of greenhouse abatement auditing. The CER publishes emissions data aggregated to registered corporations each financial year. This database provides the definitive source for carbon emissions information; however the aggregation by corporation means that the publicly-available data is not suitable for inclusion in AEMO’s models, which require intensity factors for each individual facility.

In 2014, AEMO will use revised emission intensity data published by the CER for use in the Planning Studies. For those generation facilities the CER data is not available or in a suitable form, AEMO will engage consultants to provide estimates.

⁴⁴ http://www.aemo.com.au/Electricity/Planning/Related-Information/-/media/Files/Other/planning/Planning_Studies_2013_Existing_Generator_Technical_Data_3.ashx

⁴⁵ Available from <http://www.cleanenergyfuture.gov.au/clean-energy-future/our-plan/>.

4.9.1.6 Bidding

The capacity expansion and time-sequential models contain representations of generator bidding to model reasonable behaviour and ensure that generator costs are recovered.

The capacity expansion model treats existing and new generation differently:

- Existing generators bid according to their short-run marginal cost (SRMC), the total additional cost over a short time period for a small change in output. In the model, SRMC is a combination of variable operating costs, fuel costs and emissions costs. The lower bound for SRMC for any generator is its fixed operating costs, which are incurred at an output of 0 MW. SRMC does not take into account the capital liability position of any existing generator.
- New generation bids according to its long run marginal cost (LRMC), which incorporates capital expenditure, to ensure that the cost to build new generation is recovered by the model. Once a new generator is installed, it bids in the same way as existing generators, reflecting the sunk cost of investment.

The time-sequential model may use either SRMC bidding or more detailed bidding offer curves that assign specific amounts of generation to price bands in the same way as NEMDE. The bidding offer curves do not represent the real bidding behaviour of generators in the NEM, which are not expected to continue unchanged over the timescales covered by the models. Rather, the curves are tuned such that the modelled regional price outcomes closely match historical outcomes and modelled generator capacity factors match historical capacity factors when historical conditions are modelled. This process is referred to as 'back casting'. Any specific modelling exercise that requires the inclusion of bidding offer curves will incorporate a back casting exercise.

Once set, bidding offer curves remain static throughout the modelled horizon.

As part of the Fuel and Technology cost review, Fixed and variable operating costs will be revised and published on Planning Assumptions website in June 2014⁴⁶.

4.9.1.7 Water values

The SRMC and bidding offer curve of hydroelectric generators is dependent on the value of water in storage. As storages decrease, the value of water increases due to its substitutable value in agricultural or environmental contexts, and the SRMC changes appropriately.

In capacity expansion modelling, the SRMC of a hydroelectric generator is calculated from the value of water as a varying 'fuel' cost. In time-sequential modelling, the historical bid offer curves of hydroelectric generators may not adequately reflect future response to price, because the price of electricity and the price of water are not as closely coupled as the price of electricity and the price of fuel. That is, if the price of electricity rises but the value of water does not, hydroelectric generators may over-generate, resulting in unreasonably low storage levels.

In 2013, AEMO investigated improvements to time-sequential modelling to incorporate dynamic response of water value to electricity pricing signals. The water value functions used are published as part of time sequential model on Planning Assumptions⁴⁷ website.

4.9.1.8 Minimum generation levels

The capacity expansion and time-sequential models contain a representation of the minimum stable operating point that generators are able to maintain, for both existing and new generators. These minimum generation levels reflect both the:

- Physical limitations of generating units, for example due to water hammer or furnace stability.
- Desire for generating units with large thermal inertia to avoid frequent shutdown and start-up cycles when spot prices are too low to recover variable operating costs.

In some cases, the minimum stable operating point of a generating unit is adjusted to a level below what is expected under real operational conditions. The models treat the cost of each generating unit in a power station as being equal, and when the power station is the marginal generator all of its units are

⁴⁶ See note 18.

⁴⁷ See note 18.

simultaneously marginal. The models do not contain decision-making information that allows them to decide between units, and seeks to run all units equally. Under real conditions of frequent marginality it is expected that generator operators will seek to shut down individual units where that decision is economic, and operate the remaining units closer to their optimal levels. The model is not capable of making equivalent operational decisions, so a lower minimum generation level on all units is substituted as a functionally-equivalent approach⁴⁸.

Minimum generation levels are published in either the Planning Assumptions⁴⁹ *existing generation data* or *new entry generation data* workbook as appropriate.

4.9.1.9 Outage rates

The time-sequential model uses Monte Carlo simulation to study the effect of generator outages on power system costs. Monte Carlo simulation randomly assigns a value to a variable, repeating with different random values. As the number of simulations increases, the simulation result converges to a stable value that best reflects the statistical likelihood of unpredictable events. In this case the random selection is the set of generators that are in or out of service.

AEMO collects forced outage data for each generator in the NEM, including whether a plant is entirely or partially out of service while dispatched, and the time taken to correct outages and return generation to service. This information is aggregated to form outage probability and mean time to repair statistics for each generator technology class, and used to control the Monte Carlo simulation.

The capacity expansion model does not represent time in a manner that facilitates reasonable Monte Carlo simulation. Instead, forced outage probability and mean time to repair statistics are used to reduce the capacity of generation by a small amount in every modelled time block for energy supply adequacy modelling. Forced outage information is not used for supply capacity adequacy, instead a representation of minimum reserve levels maintain generation capacity at levels that are robust to generator failure. The time-sequential model and Monte Carlo simulation are used to ensure that capacity expansion plans are reasonable under outage conditions.

In 2014, AEMO will use the most-recently collected forced outage data, published in the *Planning Assumptions*⁵⁰ *additional modelling data* workbook.

4.9.1.10 Solar energy storage

Solar thermal power plants have the capability of storing energy in the heat of their working fluid. Where storage systems are fitted to solar thermal plant, the behaviour of operators is expected to change from simply generating when energy is available to generating opportunistically based on price and the efficiency loss associated with directing energy into and retrieving energy out of storage.

Opportunistic generation depends on operators developing a forward view of price and solar energy availability long enough to inform the decision to divert energy to storage. The time-sequential model does not implement automatic look-ahead features that would enable such behaviours to be modelled explicitly.


To model opportunistic behaviour of solar generators with storage, prices are assumed to be high during the evening demand peak. The available solar energy in any day is distributed either side of this peak such that solar generators generate at maximum output during these times. This is illustrated in Figure 10 for a solar power station in Mildura with 6 hours of energy storage, on December 21. Generation is deferred to the end of the day to allow the storage to be replenished during the first half of the day, and storage is assumed to be empty at the end of each day. The total amount of energy generated is larger than that for a plant with the same power output in the same location but without storage because the presence of storage implies a larger array of mirrors (and a higher build cost) for a given maximum output.

⁴⁸ Capacity expansion and time-sequential models use single-value heat rates for each generating unit. When this is the case, two units operating at half their true minimum generation level is functionally equivalent to one unit operating at its true minimum generational level and one unit shut down.

⁴⁹ See note 18.

⁵⁰ See note 18.

Figure 10 – Solar output of a theoretical 1 MW power plant with 6 hours storage (Mildura, December 21)



4.9.1.11 Retirement candidates

The capacity expansion model allows for existing coal-fired generators to retire if simulated market signals indicate that costs may be minimised by replacing existing capacity with new capacity with a combination of lower fuel, emission or operating costs, or a location proximal to demand (reducing costs due to losses).

Generation may also be withdrawn from participation in the model if a generator has advised AEMO of its intention to decommission generating capacity.

In the capacity expansion model, very low capacity factors were observed for some coal-fired generators under some conditions during modelling in 2012, without triggering retirement. To correct for generators operating with unreasonable duty cycles, minimum capacity factor constraints were applied to the capacity expansion model.

While more robust techniques are available to manage the phenomenon of coal-fired generators becoming marginal, all require either more detailed collection of data (for example, the modelling of true heat rate curves or tuning of fixed costs), or result in significantly longer computation time (for example, modelling unit commitment, where individual units in a power station may be turned off for a period, while others continue to operate).

In 2014, AEMO will establish a small focus group to review the methodology and identify potential opportunities for improvements to the capacity expansion model and generation retirement assumptions.

4.9.2 Gas production

The gas supply-demand outlook model contains a representation of 27 gas production facilities that inject gas into the eastern and south eastern Australian gas transmission network. The representation is limited to the connection point and maximum supply capacity of each facility.

The gas supply-demand outlook model does not contain information about forced outages, production ramp rates or maintenance schedules.

Figure 11 shows the locations of modelled existing gas processing facilities, with the size of circles indicating the relative processing capacity of each facility.

In 2012, AEMO engaged CORE Energy Group to report on existing and potential gas production facilities⁵¹. AEMO is reviewing the need to update facility data in 2014.

4.9.2.1 Production costs


The gas supply-demand outlook model uses a representation of the cost of gas production at each facility to optimise network flows.

AEMO engaged CORE Energy Group in 2012 to estimate gas production costs for existing and new gas production facilities, published in *Gas Production Costs*⁵². AEMO is reviewing the need to update production cost data in 2014.

⁵¹ Available from: <http://www.aemo.com.au/Gas/Planning/Gas-Statement-of-Opportunities/Processing-Transmission-and-Storage-Facilities>.

⁵² Available from: <http://www.aemo.com.au/Gas/Planning/Gas-Statement-of-Opportunities/Production-Costs>.

Figure 11 – Gas processing facility location and relative capacity – existing facilities



4.9.3 Gas reserves

The gas supply-demand outlook model reports on the adequacy of gas reserves to meet demand in a range of future development scenarios. Reserves development is associated with gas production quantities and costs: higher production and higher costs allow more intense exploration activities which result in higher estimates of reserves. This effect is captured by the reserves to production (R/P) ratio, reported in the GSOO.

AEMO engaged CORE Energy Group in 2013 to estimate existing and potential future gas reserves, published in *Eastern & Southern Australia: Existing Gas Reserves & Resources* and *Eastern & Southern Australia: Projected Gas Reserves*⁵³.

Reserves data will be updated in 2014.

4.9.4 Electricity transmission


The capacity expansion and time-sequential models contain constraint equation-based representations of the electricity network. With the NEM explicitly modelled only on a regional basis, constraint equations model important aspects of the intra-regional networks not captured by the regional structure. This is the same approach to that used operationally in NEMDE.

4.9.4.1 Inter-regional transfer capability

All three electricity models incorporate a representation of the forward and reverse⁵⁴ transfer capability of interconnectors. These are static limits that set the maximum flow allowable in the models.

In practice, interconnector flow limits change in response to network conditions. Figure 12 shows 5-minute limits and flow on the Victoria-South Australia (Heywood) interconnector for one week in December 2012. The limits are shown to vary significantly from the static limits used in the planning models (in 2012, these were 400 MW from Victoria to South Australia, and 350 MW from South Australia to Victoria).

Figure 12 – Interconnector limits in actual operation, Heywood interconnector, 3 December to 10 December 2012



⁵³ <http://www.aemo.com.au/Gas/Planning/Gas-Statement-of-Opportunities/GSOO-2013-Supporting-Information>

⁵⁴ Each interconnector has a conventional 'forward' direction. For example, on Basslink positive or forward direction flow is from Tasmania to Victoria.

Operational interconnector limits change in response to a significant number of real-time variables that are impractical to consider in the context of long-term modelling. The application of static limits is a compromise that is simple to implement but can lead to over- or underestimation of flows. In 2012, AEMO investigated whether a new set of constraint equations could improve the modelled specification of interconnector transfer limits without imposing full operational complexity. A more complex set of constraint equations were found not to materially affect the generation and transmission expansion plans produced by the capacity expansion model, and will not be incorporated into future modelling.

4.9.4.2 Loss factors

The capacity expansion and time-sequential models' regional representation of the NEM explicitly includes each regional reference node and each interconnector. Generators and demand are 'connected' in the model to the regional reference nodes. In reality, generators are not located at the regional reference node, and the intervening network characteristic and flow pattern affects how energy that is generated at a generator appears from the perspective of the regional reference node.

To account for this difference between the true and modelled location of generators, the capacity expansion and time-sequential models contain a representation of marginal loss factors (MLFs) – the same approach used by NEMDE. These values are used to modify the amount of energy that must be dispatched from any generator, and the amount a generator is paid based on the regional reference price.

Operational MLFs are calculated by AEMO each year and published in April⁵⁵.

4.9.4.3 Constraint equations

A regional representation of the NEM is not explicitly capable of considering intra-regional power flows, either as a model result or for the purposes of modelling the physical limitations of the power system. In NEMDE, a series of network constraint equations control dispatch solutions to ensure that network limitations are accounted for. The time-sequential and electricity supply-demand calculator contain a subset of the NEMDE network constraint equations to achieve the same purpose.

The subset of network constraint equations includes approximately 1,000 pre-dispatch⁵⁶, system normal equations that model important aspects of network operation and include contingency for maintaining secure operation in the event of outage of a single network element. To ensure that modelled outcomes are suitable for the timescales considered, the selected network constraint equations represent 'usual' network capability, and specifically do not represent short-lived events such as network outages.

Both sets of stability and network constraint equations are published on the 2013 Planning Assumptions Market Simulation Information website.⁵⁷ *NTNDP Constraint Workbook*⁵⁸. This data will be updated in 2014 and published on Planning Assumptions website.

4.9.4.4 Proportioning inter-regional losses to regions

The capacity expansion and time-sequential models represent the NEM as a radial network with regions connected by notional interconnectors. Interconnectors are not perfect conductors, and power transfer between regions results in a loss of energy. AEMO uses proportioning factors to assign losses on interconnectors to regions. Operationally, this is used to determine settlement surplus. In long term modelling, proportioning factors are used to allocate losses to demand in each region.

Proportioning factors are derived from marginal loss factors, as describe in *Proportioning of Inter-Regional Losses to Regions*.⁵⁹ Proportioning factors are given in the annual *List of Regional Boundaries and Marginal Loss Factors* report.⁵⁵

⁵⁵ The 2012-13 report is available from: http://www.aemo.com.au/Electricity/Market-Operations/Loss-Factors-and-Regional-Boundaries/-/media/Files/Other/loss%20factors/MLF_2012_13_Main_Report_16_MLf.ashx.

⁵⁶ NEMDE contains equation sets for dispatch, pre-dispatch, ST PASA and MT PASA. Within these sets other sets cover specific network conditions such as outages, rate of change, frequency control ancillary services and network service agreements. Pre-dispatch equations are used because dispatch equations contain terms that rely on real-time SCADA measurements not available to simulation models.

⁵⁷ See note 18.

⁵⁸ The 2012 workbook is available from: http://www.aemo.com.au/Electricity/Planning/National-Transmission-Network-Development-Plan/-/media/Files/Other/ntndp/2012NTNDP_ConstraintWorkbook.ashx.

4.9.5 Gas transmission

The gas supply-demand outlook model contains a reduced representation of the eastern Australian gas transmission network, shown in Figure 4 and Figure 5.

In 2012, AEMO engaged CORE Energy Group to report on existing gas transmission and potential gas transmission augmentations⁵¹.

AEMO is reviewing the need to update transmission infrastructure and project proposal data for 2014.

4.9.5.1 Transmission costs

AEMO engaged CORE Energy Group in 2012 to estimate gas transmission costs for existing and new gas transmission pipelines, published in *Gas Transmission Costs*⁶⁰.

AEMO is reviewing the need to update transmission cost data in 2014.

4.10 New production and transmission

Each model defines a set of new generation or gas production projects that may be included in capacity expansion, time-sequential or gas supply-demand outlook simulations.

In capacity expansion modelling, new generators are partitioned by fuel type, technology and location within the electricity planning zone framework shown in Figure 3. Each technology will take on specific values for parameters of importance such as thermal efficiency, emission characteristics, minimum stable generation levels, standard capacities; build costs, and appropriate earliest dates for which the technology is considered current⁶¹. Each location imposes different fuel costs that reflect the fuel availability and transport requirements applicable to each zone.

The time-sequential model uses the expansion plans developed by the capacity expansion model.

The electricity supply-demand calculator includes committed generation and transmission projects only.

The gas supply-demand outlook model includes committed production and transmission projects and a selection of proposals that are assessed for their efficacy in eliminating supply shortfall.

4.10.1 Committed, advanced, proposed and conceptual

New production and transmission projects fall into one of four classes of certainty:

- **Committed:** projects that will proceed, with known timing, satisfying all five of the commitment criteria outlined in Table 2. These criteria apply to electricity investments. There are no equivalent commitment criteria for gas projects; however the principals of commitment outlined in Table 2 are applied for the purposes of gas modelling. The costs of committed projects are considered sunk for the purposes of modelling: because there is no investment decision that is calculable for committed projects, their costs are not included in any of the market models.
- **Advanced:** projects that satisfy at least three, but not all of the commitment criteria, and for which commissioning timing is in doubt. In electricity modelling, advanced projects are tested for economic efficiency in the capacity expansion model. In gas modelling, advanced projects are considered as candidates to relieve supply shortfall for the purposes of reserves adequacy assessment.
- **Proposals:** projects that have fewer than three of the commitment criteria, uncertain timing, and which are strongly subject to changes in the commercial environment. In general, projects classed as proposals do not have sufficient definition to justify special consideration in capacity expansion or gas supply-demand modelling. AEMO uses generic conceptual projects in these cases.
- **Conceptual:** capacity that belongs to a technology class and which may be required to satisfy reserve requirements, but for which no proposal has been forwarded. Conceptual projects include items such as a generic OCGT or CCGT generator, or a pipeline project of a specific length,

⁵⁹ Available from: <http://www.aemo.com.au/Electricity/Market-Operations/Loss-Factors-and-Regional-Boundaries/~media/Files/Other/electricityops/0170-0003%20pdf.ashx>.

⁶⁰ Available from: <http://www.aemo.com.au/Gas/Planning/Gas-Statement-of-Opportunities/Transmission-Costs>.

⁶¹ Technologies that are not yet in commercial development are assigned an earliest build date.

diameter and pressure class. Costs and capabilities of these projects are developed using recently-completed projects and projections of cost components such as raw material supply and labour.

Table 2 - Commitment criteria

Category	Criteria
Site	The proponent has purchased/settled/acquired land (or legal proceedings have commenced) for the construction of the proposed development.
Major components	Contracts for the supply and construction of the major components of plant or equipment (such as generating units, turbines, boilers, transmission towers, conductors, and terminal station equipment) should be finalised and executed, including any provisions for cancellation payments.
Planning consents/ construction approvals/EIS	The proponent has obtained all required planning consents, construction approvals, and licences, including completion and acceptance of any necessary environmental impact statements (EIS).
Finance	The financing arrangements for the proposal, including any debt plans, must have been concluded and contracts executed.
Final construction date set	Construction must either have commenced or a firm commencement date must have been set.

4.10.2 New production projects

4.10.2.1 Electricity

Committed new generation projects will be sourced from AEMO’s Generator Information Page, using the latest information available when modelling begins. Committed generation projects are included, with fixed timing and without build costs, in all electricity modelling.

Conceptual projects are developed using a combination of the data in *Cost of Construction New Generation Technology* and *Fuel cost projections: Natural gas and coal outlooks for AEMO modelling*. The capacity expansion model develops a generation expansion plan for each studied scenario, published with the NTNDP. The plant configurations selected as candidates for entry in expansion plans are included in the capacity expansion model. The 2012 capacity expansion model is available from the 2012 NTNDP Assumptions and Inputs web page⁶². For convenience, conceptual plant technical data is also available in the 2013 new entry generation workbook available from the same web page. The 2012 generation expansion plans are available at AEMO’s 2012 NTNDP Detailed Results web page⁶³.

A 2013 new entry generation data workbook, containing updated information where applicable, accompanies this document.

4.10.2.2 Gas

For electricity, committed projects are those that satisfy AEMO’s five commitment criteria, listed in Table 2. There are no equivalent commitment criteria defined for gas production, however the principals of commitment in Table 2 are applied to gas projects for modelling purposes.

In 2012 AEMO engaged CORE Energy Group to survey and report on gas production, storage and transmission projects⁵¹.

AEMO is reviewing the need to update committed gas projects for 2013.

⁶² <http://www.aemo.com.au/Electricity/Planning/National-Transmission-Network-Development-Plan/Assumptions-and-Inputs>.

⁶³ <http://www.aemo.com.au/Electricity/Planning/National-Transmission-Network-Development-Plan/Detailed-Results>.

4.10.2.3 Production build limits

In capacity expansion modelling, the maximum amount of new generation of any technology type that can be established in any zone is limited in the model (“build limits”). New generation or production in other modelling is limited either to the generation expansion plan developed by the capacity expansion modelling (the time-sequential model), or the committed status of new generation projects (electricity supply-demand calculator and gas supply-demand outlook model).

There are two major sources of information behind the build limit assumptions – advice provided by ACIL Tasman as input into the 2010 NTNDP, and further refinement through network studies and TNSP advice during the 2012 NTNDP analysis itself. The limits provided by ACIL Tasman were intended to primarily reflect issues around access to fuel and land. Some aspects of labour and construction resource availability may have been included, though these weren’t documented in ACIL’s report.

AEMO will review the build limit assumptions following fuel and technology cost review in early 2014.

Once an investment pattern is produced using the build limits, more detailed work is undertaken to explore the impact this would have on the network – and the costs of resolving any issues. In some cases, this leads us to modify the build limits to ensure that our (less detailed) investment model has some visibility of the (more-detailed) network limitations. This process of iteration can be repeated several times to settle on the final set of build limits used by the model.

4.10.3 New transmission projects

4.10.3.1 Electricity

Committed electricity transmission projects are incorporated into both the time-sequential and the capacity expansion models. The effect of committed projects on the network is implemented as modifications to the network constraint equations that control flow.

The capacity expansion model includes representations of the effect on the network and the cost of advanced and proposed electricity transmission projects. The model selects projects for inclusion in future network development based on their ability to reduce total costs.

AEMO surveys transmission projects suggested by jurisdictional planning bodies⁶⁴ in annual planning reports (APRs). These projects are summarised and published in the *Annual Planning Reports Project Summary* workbook⁶⁵. A subset of these projects is selected for inclusion in the capacity expansion model. AEMO may also develop new transmission projects where study requirements are not met by the APR survey.

4.10.3.2 Gas

The gas supply-demand outlook model considers the effect of new transmission projects on energy flow in the network. The model does not select from among a number of options like the capacity expansion model. Rather, when supply shortfall is reported that may be alleviated with a transmission project, the transmission project can be included to test its ability to restore supply.

In 2012, AEMO engaged CORE Energy Group to estimate the capability and costs of new gas transmission projects, and to survey committed gas transmission projects, published in *Review of Gas Facilities: Existing and New* and *Gas Transmission Costs*. Projects to alleviate supply shortfall were selected from the proposals listed in those documents.

The 2013 Gas supply-demand outlook model is available on AEMO’s Gas Statement of Opportunities website.⁶⁶

⁶⁴ In Queensland, Powerlink. In New South Wales, Transgrid. In Victoria, AEMO. In South Australia, ElectraNet. In Tasmania, Transend.

⁶⁵ Available from:
http://www.aemo.com.au/Electricity/Planning/~/_/media/Files/Electricity/Planning/Reports/NTNDP/2013/Annual%20Planning%20Reports%20Project%20Summary.xlsx.ashx.

⁶⁶ <http://www.aemo.com.au/Gas/Planning/Gas-Statement-of-Opportunities/GSOO-2013-Supply-Demand-Modelling-files>

5 Analysis

5.1 Market benefits

Some modelling exercises are designed to determine the benefit to the market delivered by specific augmentation projects.

Where calculation of market benefits is warranted, time-sequential modelling will be used to developed detailed hour-by-hour costs in both of:

- The case in which an augmentation project is not present.
- The case in which the augmentation is present.

The difference in cost between these two cases is the market benefit of the augmentation. Where an augmentation is expected to affect the development of generation, a generation expansion plan will be developed for each case.

The potential market benefits resulting from a selected augmentation are assessed through the market simulation outcomes, and may include capital cost deferral, operating cost, losses and reliability benefits.

5.1.1 Generation capital costs

An augmentation may defer generation capital expenditure, saving the cost to finance investment during the deferral period. In extreme cases, generation may not need to be built at all.

An augmentation may allow a less capital-intensive form of generation to be established in an alternate location.

Generation capital deferral benefits are determined by capacity expansion modelling outcomes.

5.1.2 Transmission capital costs

An augmentation may defer the need to build other transmission projects.

Transmission capital deferral benefits are determined by capacity expansion modelling outcomes.

5.1.3 Operating costs

An augmentation may relieve limitations on existing or new generation with lower fuel, emissions, fixed or variable operating costs, allowing lower-cost generation to operate more frequently.

Operating cost benefits are determined by time-sequential modelling outcomes.

5.1.4 Transmission system losses

An augmentation may allow generation to be dispatched closer⁶⁷ to the locations where energy is consumed, reducing the cost to transport energy on the network.

An augmentation may change the flow patterns on interconnectors in ways that reduce losses when transferring power between regions.

Transmission system loss benefits are determined by capacity expansion modelling outcomes (when new generation is established closer to load centres) and time-sequential modelling outcomes (when changes in network limitations change interconnector flow patterns).

5.1.5 Changes in involuntary load shedding (reliability benefits)

The Reliability Standard⁶⁸ imposes a strict ceiling on the amount of unserved energy (USE) that can be tolerated by consumers in the power system. VCR is used in planning studies and economic assessments to

⁶⁷ Electrical proximity. That is, substituted generation may be physically further away, but connected to a lower-loss transmission line, or operates in a way that reduces total losses in delivering energy to the point of consumption.

⁶⁸ 0.002% of total annual energy per region per financial year. See <http://www.aemc.gov.au/panels-and-committees/reliability-panel/guidelines-and-standards.html>.

represent the value that consumers place on supply reliability – so that investment options can be compared on an economic basis.

AEMO last reviewed the value of customer reliability in 2012.⁶⁹ A pilot survey was carried out in late 2013 to test the methodology and survey approach on both residential and business customers. AEMO is currently assessing the results from the pilot process, but it is very likely that some amendments to the initial methodology will be needed to ensure robust VCR results can be delivered on a wider national scale. AEMO is intending to publish draft results in 2014.

An augmentation may reduce the amount of reported unserved energy, reducing the penalties associated with failing to supply consumers.

Reliability benefits tend to be small, because the Reliability Standard already imposes low limits on unserved energy that must be met.

Reliability benefits are determined by time-sequential modelling outcomes.

The sum of the reliability, operating cost, capital cost, and reduced loss benefits represents the total market benefits of an augmentation. Comparing these potential market benefits with the cost of the augmentation provides an insight into whether this project is likely to be justified under the Australian Energy Regulator's (AER) Regulatory Investment Test for Transmission (RIT-T).

In the presence of an augmentation, the individual cost components of market benefits may be greater or less than the same cost components in the case where the augmentation is absent. For example, it is common for large operating cost benefits to be associated with a negative capital cost benefit: money is spent to build new, more expensive generation that subsequently has much lower operating costs. Wind generation is an example of generation that may increase initial capital cost but greatly reduce operating costs compared to thermal plant that must pay fuel and emission costs for the duration of their working lifetime.

5.1.6 Option value and competition benefits

AEMO's planning modelling does not quantify option value or competition benefits. These value propositions require a specificity of analysis that is not practical for or aligned with AEMO's holistic view of network infrastructure.

5.2 Financial settings

Cost-benefit comparisons between augmented and unaugmented cases use a discounted cash flow (present value) calculation to determine the value to the market in the present day of spending that occurs in the future.

5.2.1 Inflation

Monetary values in the models refer to real value, as opposed to nominal value. That is, future values are not adjusted by assumptions about inflation, whereas values defined in the past are adjusted to account for inflation. For example, in 2014 values are expressed in 2014-15 Australian dollars. Values that were originally expressed in 2013-14 dollars and re-used in 2014 will be adjusted upwards by 2.5% to account for inflation.⁷⁰

5.2.2 Goods and Services Tax

Prices are exclusive of Goods and Service Tax.

5.2.3 Weighted average cost of capital

The capital cost of an investment is increased beyond its purchase price by the cost of finance. The weighted average cost of capital (WACC) is the rate that a company is willing to pay to finance its assets.⁷¹ The WACC

⁶⁹ Available at <http://www.aemo.com.au/Electricity/Policies-and-Procedures/Planning/National-Value-of-Customer-Reliability-VCR>.

⁷⁰ Inflation is calculated from Australian Bureau of Statistics consumer price index adjustments (Catalogue item 6401.0).

⁷¹ The return the company would expect to receive from an alternative investment with similar risk.

is the weighted sum of the cost of debt and the cost of equity, where the cost of debt is determined by interest rates, and the cost of equity is determined by reference against the returns received by other projects with similar risk.

AEMO uses real, pre-tax WACC values developed by ACIL Tasman for Energy White Paper modelling. **Error! Bookmark not defined.** Values may vary by scenario reflecting the difficulty in obtaining credit under different economic conditions.

5.2.4 Discount rate

Present value calculations estimate all future cash flows which are discounted to account for the amount of cash that would need to be invested in the present day to yield the same future cash flow.

AEMO may use a range of discount rates to estimate future cash flows. Practically, lower discount rates emphasise market benefits that accrue later in the modelled horizon, while higher discount rates emphasise market benefits that accrue earlier in the modelled horizon. A higher discount rate can be used to accommodate the uncertainty inherent in the estimates of cost to operate modelled energy infrastructure, which increases with time.

Values may vary by scenario reflecting the difficulty in obtaining credit under different economic conditions.

5.2.5 Project lifetime

Augmentation costs are annualised over 40 years using a terminal value to represent annual costs beyond the final simulation year. The market simulations simulate up to a 25-year outlook period whereas the cost benefit analysis is performed over a 40-year period due to the long life of the assets involved. A terminal value is estimated to represent the value of ongoing annual market benefits from the end of the simulated outlook period through to the end of the net present value period. The terminal value is estimated by assuming that average market benefits observed in the final simulated years are the same as future years. In a context of growing demand, this constitutes a conservative assumption that growing demand does not result in higher utilisation of assets.

Appendix A. Summary of information sources

Table 3 – Summary of information sources


Information	Section	Source
Scenario descriptions	2	<p><i>2014 Scenarios Descriptions</i></p> <p>Available from http://www.aemo.com.au/ http://www.aemo.com.au/Electricity/Planning/Related-Information</p>
Adjustment to demand due to rooftop PV	4.1.2	<p><i>Rooftop PV Information Paper 2012</i></p> <p>The 2012 report is available from http://www.aemo.com.au/Electricity/Planning/Forecasting/~media/Files/Other/forecasting/Rooftop_PV_Information_Paper_20_June_2012.ashx</p>
Regional electricity energy and maximum demand forecasts	4.1	<p>Part of the <i>National Electricity Forecasting Report</i></p> <p>The 2013 report is available from http://www.aemo.com.au/Electricity/Planning/Forecasting/National-Electricity-Forecasting-Report-2013.</p> <p>Data is available from http://www.aemo.com.au/Electricity/Planning/Forecasting/National-Electricity-Forecasting-Report-2013.</p> <p>This report will be updated in 2014.</p>
Generation inventory	4.9.1	<p>AEMO-internal database.</p> <p>Relevant data may be obtained from AEMO’s online Generation Information Page, available at http://www.aemo.com.au/Electricity/Planning/Related-Information/Generation-Information.</p> <p>This data is updated as new information is received.</p>
Minimum reserve levels	4.4	<p>Reviewed by AEMO on an as-needed basis.</p> <p>The last review was performed in 2010. The latest reserve level discussion is available at http://www.aemo.com.au/Electricity/Market-Operations/Reserve-Management/Regional-Minimum-Reserve-Levels.</p>
New generation technology costs	4.10.2	<p><i>Cost of Construction New Generation Technology (Worley Parsons)</i></p> <p>The 2012 report is available from http://www.aemo.com.au/Electricity/Planning/National-Transmission-Network-Development-Plan/~media/Files/Other/planning/WorleyParsons_Cost_of_Construction_New_Generation_Technology_2012%20pdf.ashx</p> <p>These costs will be reviewed as part of the fuel and technology cost review and published by June 2014.</p>
Committed and proposed transmission augmentations	4.10.3	<p><i>Annual Planning Reports Project Summary</i> workbook</p> <p>The 2013 summary is available from http://www.aemo.com.au/Electricity/Planning/~media/Files/Electricity/Planning/Reports/NTNDP/2013/Annual%20Planning%20Reports%20Project%20Summary.xlsx.ashx</p> <p>This data will be updated in 2014.</p>
Significant constraint	4.9.4.3	<p><i>NTNDP Constraint workbook</i></p>

Information	Section	Source
equations		<p>The 2013 Stability constraints workbook is available from http://www.aemo.com.au/Electricity/Planning/Related-Information/~/_media/Files/Other/planning/2013_Stability_Constraints_workbook.ashx</p> <p>The 2013 thermal constraints workbook is available from http://www.aemo.com.au/Electricity/Planning/Related-Information/~/_media/Files/Other/planning/2013_Thermal_Constraints_workbook.ashx</p> <p>This data will be updated in 2014.</p>
Emissions intensity factors	4.9.1.5	<p>Existing plant: <i>Fuel resource, new entry and generation costs in the NEM</i> (ACIL Tasman)</p> <p>Emissions intensity factors were last published in 2009, and are available at www.aemo.com.au/planning/419-0035.pdf. For 2014, AEMO will be compiling a new dataset using National Greenhouse and Energy Reporting data.</p> <p>New plant: <i>Cost of Construction New Generation Technology</i> (Worley Parsons)</p> <p>The 2012 report is available from http://www.aemo.com.au/Electricity/Planning/National-Transmission-Network-Development-Plan/~/_media/Files/Other/planning/WorleyParsons_Cost_of_Construction_New_Generation_Technology_2012%20pdf.ashx</p> <p>This data will be updated in 2014.</p>
Marginal loss factors and proportioning factors	4.9.4.2	<p><i>List of Regional Boundaries and Marginal Loss Factors for the 2013-14 Financial Year</i></p> <p>The 2013 report is available from http://www.aemo.com.au/Electricity/Market-Operations/Loss-Factors-and-Regional-Boundaries/~/_media/Files/Other/loss%20factors/MLF_2013_14_Final.ashx</p> <p>This data will be updated in 2014.</p>
Carbon price trajectories	4.2.5	<p>Part of the <i>2013 National Electricity Forecasting Report</i></p> <p>2013 carbon price trajectories are included in the <i>2013 additional modelling data</i> workbook.</p> <p>The carbon price trajectories will be updated in 2014.</p>
Renewable energy targets	4.2.1	<p><i>The Large-scale Renewable Energy Target (LRET)</i> (Clean Energy Regulator)</p> <p>LRET targets are available from http://ret.cleanenergyregulator.gov.au/About-the-Schemes/lret</p> <p>A review released in December 2012 (available from http://climatechangeauthority.gov.au/ret) indicated that renewable energy targets would not be adjusted to account for reduced demand growth.</p>
Gas and coal prices	4.5 and 4.6	<p><i>Fuel cost projections: Natural gas and coal outlooks for AEMO modelling</i> (ACIL Tasman)</p> <p>The 2012 report is available from http://www.aemo.com.au/Consultations/National-Electricity-Market/Open/~/_media/Files/Other/planning/Fuel_cost_projections_Natural_gas_and_coal_outlooks.ashx</p> <p>This data will be updated for 2014</p>
Gas annual and	4.1	<p><i>Gas Statement of Opportunities</i></p>

Information	Section	Source
peak day demand forecasts		The 2013 report and accompanying datasets are available from http://www.aemo.com.au/Gas/Planning/Gas-Statement-of-Opportunities .
Existing and new gas production, storage and transmission infrastructure	4.9.2, 4.9.5, 4.10.2.2 and 4.10.3.2	<p><i>Review of Gas Facilities: Existing and New</i> (CORE Energy Group)</p> <p>The 2012 report is available from http://www.aemo.com.au/Gas/Planning/Gas-Statement-of-Opportunities/~/_media/Files/Other/planning/Amended_Review_of_Gas_Facilities_Existing_and_New.aspx.</p> <p>Accompanying data is available from http://www.aemo.com.au/Gas/Planning/Gas-Statement-of-Opportunities/~/_media/Files/Other/planning/Gas%20Facilities%20Accompanying%20Data%20xlsx.aspx.</p> <p>This data will be updated in 2013.</p>
Gas production and transmission costs	4.9.2.1 and 4.9.5.1	<p><i>Gas Production Costs and Gas Transmission Costs</i> (CORE Energy Group)</p> <p>Latest reports and data are available from http://www.aemo.com.au/Gas/Planning/Gas-Statement-of-Opportunities/Production-Costs and http://www.aemo.com.au/Gas/Planning/Gas-Statement-of-Opportunities/Transmission-Costs.</p> <p>These data will not be updated for 2013.</p>
Gas reserves	4.9.3	<p><i>Eastern & Southern Australia : Existing Gas Reserves & Resources</i> and <i>Eastern & Southern Australia : Projected Gas Reserves</i> (CORE Energy Group)</p> <p>Latest reports and data are available from http://www.aemo.com.au/Gas/Planning/Gas-Statement-of-Opportunities/2012-Supporting-Information</p> <p>This data will be updated in 2013.</p>
Projections of demand for LNG export	4.1	<p><i>Eastern & South-Eastern Australia : Projections of Gas Demand for LNG Export</i> (CORE Energy Group)</p> <p>Latest reports and data are available from http://www.aemo.com.au/Gas/Planning/Gas-Statement-of-Opportunities/Liquid-Natural-Gas-Projections</p> <p>This data will be updated in 2013.</p>
Wind contribution to peak demand	4.7.1.1	<p><i>Wind Contribution to Peak Demand</i></p> <p>The latest report is available from http://www.aemo.com.au/Electricity/Planning/Related-Information/Wind-Contribution-to--Peak-Demand</p> <p>This data will be updated in 2013</p>
Demand side participation amounts	4.3.1	<p><i>2013 additional modelling data</i> workbook</p> <p>The latest dataset is available from http://www.aemo.com.au/Electricity/Planning/National-Transmission-Network-Development-Plan/Assumptions-and-Inputs</p> <p>This data will be updated in 2013</p>
Auxiliary loads	4.9.1.3	<p>Regional data is part of the <i>2012 National Electricity Forecasting Report</i></p> <p>The 2012 report is available from http://www.aemo.com.au/Electricity/Planning/Forecasting/~/_media/Files/Other/f</p>

Information	Section	Source
		<p>orecasting/2012%20National%20Electricity%20Forecasting%20Report.ashx.</p> <p>Data is available from http://www.aemo.com.au/Electricity/Planning/Forecasting/Forecasting-Data-2012.</p> <p>This report will be updated in 2013.</p> <p><i>Consolidated 2013 plant technical data</i> contains auxiliary load for each existing generating unit and each class of new generating unit</p>
Generator ramp rates	4.9.1.2	<p><i>2013 existing generation data</i> workbook</p> <p>The latest dataset is available from http://www.aemo.com.au/Electricity/Planning/National-Transmission-Network-Development-Plan/Assumptions-and-Inputs</p>
Forced outage rates	4.9.1.9	<p><i>2013 additional modelling data</i> workbook</p> <p>The latest dataset is available from http://www.aemo.com.au/Electricity/Planning/National-Transmission-Network-Development-Plan/Assumptions-and-Inputs</p>
Water values	4.9.1.7	<p><i>2013 additional modelling data</i> workbook</p> <p>The latest dataset is available from http://www.aemo.com.au/Electricity/Planning/National-Transmission-Network-Development-Plan/Assumptions-and-Inputs</p>
Reliability Standard	5.1.5	<p><i>Reliability Standards</i> (AEMC)</p> <p>Available from the AEMC website at http://www.aemc.gov.au/panels-and-committees/reliability-panel/guidelines-and-standards.html</p>

Appendix B. Energy Planning Reports: Overview



Appendix C. Data flow

Data referenced in this report are used in a range of documents produced by AEMO. The following diagrams show the process flow of each major document, to facilitate understanding of how data is incorporated into modelling and reporting activities.

Figure 13 – Electricity Statement of Opportunities process flow diagram




Figure 14 – Gas Statement of Opportunities process flow diagram




Figure 15 – National Transmission Network Development Plan process flow diagram




Figure 16 – South Australian Supply Demand Outlook process flow diagram




Figure 17 – Victorian Annual Planning Report process flow diagram

