Statement:

1. External label ((L125 CA 23) Character height 37.5mm complies with SA/SNZ TS 1158 clause 1.6.3 marking is legible and weatherproof.

2. The luminaires will be controlled via a PE cell in a nearby switchboard. The luminaires will be fitted with a “shorting cap” in the NEMA socket.

3. Load Test Conducted by Light Emission Laboratory was fitted with Shorting Cap. We have done in house test with PE cell and results were satisfactory.

Thanking you,

Raj Bhat CEng MIET FIHE MIEEE EUR ING

Chartered Engineer

Managing Director

Illuminating Power Technologies Pty Ltd

Reg. Office:5A/251, Queen Street, Campbelltown NSW 2560
Email: info@illuminatingpowertechnologies.com.au
Phone: +61 2 98944464. Mobile: +61 439168898

Certified ISO 9001:2015 Quality Management
Certified ISO 45001:2018 Health & Safety Management