

Light Emission Distribution Laboratory Division of Photometry & Electrical Testing Pty. Ltd ABN 11 166 255 134 All tests conducted at Unit 4, 140 George St, Hornsby NSW 2077 Australia Ph: +61 2 9476 3097 E: info@ledlab.com.au



Test Report: 230625LCP

Testing of Road Light Power for AEMO's NEM Load Table for Unmetered Loads on Road lighting luminaires

For Q-RAY 125W LED Streetlight

Type of product: CAT V LED Streetlight
Model Number: IPT-QR-125W v3-27-IP66
Prepared for: Illuminating Power Technologies Pty Ltd
Description: 125W LED Streetlight. Features die-cast aluminium body, glass diffuser, polycarbonate lens assemblies, an LED board (marked \$280WL120-1P6 REV A) powered from an Inventroncs LED driver (model number EUM-150S105DG).

Test objective

Determination of the luminaire supply operating parameters Voltage, Current, Power and Power Factor when tested at nominal test voltages of 250V. By the method of LEDLab Electrical Parameter Determination and AEMO Unmetered_Load_Guideline_v2_0.

Test configuration

The ten luminaires were operated at 25°C ambient temperature in their normal operational orientation at 250VAC, 50Hz, until the monitored luminaire stabilised as defined in IES LM79. Twenty readings were taken ten seconds apart and the average found. The average value is multiplied by the Calibration Correction given in the latest NATA endorsed calibration report then has Voltmeter losses subtracted based on Watt-meter input impedance and test voltage. The other nine luminaires having operated for the same or more time are switched one by one to Wattmeter for their twenty readings.

Client

Contact Raj Bhat, 5A/251, Queen Street, Campbelltown NSW 2560

Conclusions

The Average Load (W) is 123.92W at 0.937 Power Factor.

Tested by:

29/06/2023

David Orwin

Authorised Signatory

David Ford

Date: 30/06/2023

The data specified in this report relates to the sample measured as received from the client under standard conditions specified in the Test Specification and may not necessarily relate to other similar luminaires or other operating conditions. The tests and measurements covered by this document are traceable to Australian national standards of measurement. This report shall only be reproduced in full unless approved in writing by Light Emission Distribution Laboratory (LEDLab). The test was performed at Hornsby Laboratory, Unit 4, 140 George St., Hornsby, NSW 2077, Australia.



Results

Final value

Time till stabilisation: 3h

Electrical Measurements

	Supply	Input		Davian
Sample 1	Voltage	Current	Input Power	Power
	(Vrms)	(Arms)	(W)	Factor
Average	248.792	0.530	123.736	0.938
Min	248.792	0.530	123.736	0.938
Max	248.792	0.530	123.736	0.938
Calibration correction	1.00334	1.00000	1.00297	1.0000
Instrument impedance correction	0.000	0.00024	0.0576	
Final value	249.62	0.530	124.10	0.938
		•		
	Supply	Input	Input Power	Power
Sample 2	Voltage	Current	(W)	Factor
	(Vrms)	(Arms)	(00)	Tactor
Average	249.475	0.530	124.064	0.938
Min	249.391	0.530	123.875	0.938
Max	249.590	0.530	124.202	0.939
Calibration correction	1.00334	1.00000	1.00297	1.0000
Instrument impedance correction	0.000	0.00024	0.0576	
Final value	250.31	0.530	124.43	0.938
	-			
	Supply	Input	Input Power	Power
Sample 3	Voltage	Current	(W)	Factor
	(Vrms)	(Arms)		
Average	249.590	0.528	123.318	0.936
Min	249.590	0.527	123.251	0.936
Max	249.590	0.528	123.384	0.937
Calibration correction	1.00334	1.00000	1.00297	1.0000
Instrument impedance correction	0.000	0.00024	0.0576	

The he tests and measurements covered by this document are traceable to Australian national standards of measurement.

This report only applies to the items tested as received from the client and shall only be reproduced in full unless approved in writing by Light Emission Distribution Laboratory (LEDLab).

250.42

0.528

123.68

0.936



	Supply	Input	Input Power	Power
Sample 4	Voltage	Current	(W)	Factor
	(Vrms)	(Arms)	(VV)	Factor
Average	249.585	0.529	123.774	0.937
Min	249.490	0.528	123.520	0.937
Max	249.590	0.530	124.025	0.938
Calibration correction	1.00334	1.00000	1.00297	1.0000
Instrument impedance correction	0.000	0.00024	0.0576	
Final value	250.42	0.529	124.14	0.937
		1	1	
	Supply	Input	Input Power	Power
Sample 5	Voltage	Current	(W)	Factor
	(Vrms)	(Arms)		
Average	249.590	0.528	123.317	0.936
Min	249.590	0.527	123.251	0.936
Max	249.590	0.528	123.373	0.937
Calibration correction	1.00334	1.00000	1.00297	1.0000
Instrument impedance correction	0.000	0.00024	0.0576	
Final value	250.42	0.528	123.68	0.936
			1	
	Supply	Input	Input Power	Power
Sample 6	Voltage	Current	(W)	Factor
	(Vrms)	(Arms)	122.462	0.020
Average	249.102	0.529	123.463	0.938
Min	248.992	0.528	123.366	0.938
Max	249.800	0.529	123.526	0.939
Calibration correction	1.00334	1.00000	1.00297	1.0000
Instrument impedance correction	0.000	0.00024	0.0576	1.0000
Final value	249.94	0.00024 0.529	123.83	0.938
	249.94	0.529	123.83	0.938



	•			
	Supply	Input	Input Power	Power
Sample 7	Voltage	Current		
	(Vrms)	(Arms)	(W)	Factor
Average	249.616	0.529	123.513	0.936
Min	249.490	0.528	123.467	0.936
Max	250.300	0.529	123.561	0.937
Calibration correction	1.00334	1.00000	1.00297	1.0000
Instrument impedance correction	0.000	0.00024	0.0576	
Final value	250.45	0.529	123.88	0.936
		1		
	Supply	Input	Input Power	Power
Sample 8	Voltage	Current	(W)	Factor
	(Vrms)	(Arms)	(••)	Tactor
Average	249.570	0.528	123.368	0.935
Min	249.490	0.528	123.328	0.935
Max	249.690	0.529	123.436	0.936
Calibration correction	1.00334	1.00000	1.00297	1.0000
Instrument impedance correction	0.000	0.00024	0.0576	
Final value	250.40	0.528	123.73	0.935
	1	Γ	1	
	Supply	Input	Input Power	Power
Sample 9	Voltage	Current	(W)	Factor
	(Vrms) (Arms)			
Average	249.645	0.528	123.360	0.936
Min	249.590	0.527	123.290	0.934
Max	249.690	0.529	123.401	0.938
Calibration correction	1.00334	1.00000	1.00297	1.0000
Instrument impedance correction	0.000	0.00024	0.0576	
Final value	250.48	0.528	123.73	0.936



Sample 10	Supply Voltage (Vrms)	Input Current (Arms)	Input Power (W)	Power Factor
Average	249.610	0.528	123.666	0.939
Min	249.590	0.528	123.628	0.939
Max	249.690	0.528	123.690	0.939
Calibration correction Instrument impedance correction	1.00334 0.000	1.00000 0.00024	1.00297 0.0576	1.0000
Final value	250.44	0.528	124.03	0.939

Table 1. Electrical operating parameters of Q-RAY 125W LED Streetlight

Sample No.	Supply Voltage (Vrms)	Input Current (Arms)	Input Power (W)	Power Factor
Sample 1	249.62	0.530	124.10	0.938
Sample 2	250.31	0.530	124.43	0.938
Sample 3	250.42	0.528	123.68	0.936
Sample 4	250.42	0.529	124.14	0.937
Sample 5	250.42	0.528	123.68	0.936
Sample 6	249.94	0.529	123.83	0.938
Sample 7	250.45	0.529	123.88	0.936
Sample 8	250.40	0.528	123.73	0.935
Sample 9	250.48	0.528	123.73	0.936
Sample 10	250.44	0.528	124.03	0.939
Average	250.29	0.529	123.92	0.937

Uncertainties

At a Confidence Level of 95% with a Coverage Factor of 2:

Supply Voltage: ± 0.07% Supply Current: ± 0.14% Supply Power: ± 0.19% Power Factor: ± 0.005 Ambient Temperature: ± 1°C

Test Equipment Used

Power meter: Clarke Hess Model 2335 Power meter integration time (s): 5 Calibration Report: PlusEs report no. 52164 Luminaire thermometer: AMA S No. 1086110-0.1deg

The he tests and measurements covered by this document are traceable to Australian national standards of measurement.

This report only applies to the items tested as received from the client and shall only be reproduced in full unless approved in writing by Light Emission Distribution Laboratory (LEDLab).



General Photographs



Photo 1. Luminaire.



Photo 2. Luminaire.



Photo 3. LED optical opening.



Photo 4. LED driver.





Photo 5. Luminaire geartray.




Photo 6. Luminaire label.