

Light Emission Distribution Laboratory Division of Photometry & Electrical Testing Pty. Ltd ABN 11 166 255 134 All tests conducted at Unit 4, 140 George St, Hornsby NSW 2077 Australia Ph: +61 2 9476 3097 E: info@ledlab.com.au



# Test Report: 230140LCP

# Testing of Road Light Power for AEMO's NEM Load Table for Unmetered Loads on Road lighting luminaires

for StreetLED3 LED 11W 4K SPD FTB D

*Type of product:* LED Streetlight

Model Number: JLC99Z06L11

Prepared for: Sylvania Schréder

Description: 11W LED Streetlight. Class II luminaire rated as 11W, 0.049A, 240V, 50Hz, 0.9PF. Optical: IP66, Gear: IP24, Ta:40C. IK:06. Features die-cast aluminium housing and polycarbonate optical cover and lens. Schréder LED board (model no. ESC73001546V10R15) driven from Osram LED driver (model no. Icutronic IT DALI 20/220-240/350 P5).

#### **Test objective**

Determination of the luminaire supply operating parameters Voltage, Current, Power and Power Factor when tested at nominal test voltages of 250V. By the method of LEDLab Electrical Parameter Determination and AEMO Unmetered\_Load\_Guideline\_v2\_0.

#### **Test configuration**

The ten luminaires were operated at 25°C ambient temperature in their normal operational orientation at 250VAC, 50Hz, until the monitored luminaire stabilised as defined in IES LM79. Twenty readings were taken and the average found. The average value is multiplied by the Calibration Correction given in the latest NATA endorsed calibration report then has Voltmeter losses subtracted based on Watt-meter input impedance and test voltage. The other nine luminaires having operated for the same or more time are switched one by one to Wattmeter for their twenty readings.

#### Client

Contact Swati Dhembre, Sylvania Schréder, Bldg 4A, Parklands Estate, 21-23 South Street, Rydalmere, NSW 2116

#### Conclusions

The Average Load (W) is 11.46W at 0.938 Power Factor.

Tested by:

24/01/2023

Adrian Gagla

Authorised Signatory

David Ford

Date: 25/01/2023

The data specified in this report relates to the sample measured as received from the client under standard conditions specified in the Test Specification and may not necessarily relate to other similar luminaires or other operating conditions. The tests and measurements covered by this document are traceable to Australian national standards of measurement. This report shall only be reproduced in full unless approved in writing by Light Emission Distribution Laboratory (LEDLab). The test was performed at Hornsby Laboratory, Unit 4, 140 George St., Hornsby, NSW 2077, Australia.



#### Results

Time till stabilisation: 2h

#### **Electrical Measurements**

| Sample 1  | Supply<br>Voltage<br>(Vrms) | Input Current<br>(Arms) | Input Power<br>(W) | Power Factor |
|---|-----------------------------|-------------------------|--------------------|--------------|
| Average   | 250.282                     | 0.049                   | 11.355             | 0.935        |
| Min   | 250.109                     | 0.049                   | 11.352             | 0.935        |
| Max   | 250.440                     | 0.049                   | 11.357             | 0.935        |
| Calibration correction (see Newton 4th calibration report 2020002794) | 1.00025                     | 0.99958                 | 1.00010            | 1.0000       |
| Instrument impedance correction (N4)                                  | 0.000                       | 0.00024                 | 0.0576             |              |
| Final value   | 250.34                      | 0.049                   | 11.36              | 0.935        |
|   |                             | 1                       | Γ                  | 1            |
| Sample 2  | Supply<br>Voltage<br>(Vrms) | Input Current<br>(Arms) | Input Power<br>(W) | Power Factor |
| Average   | 250.290                     | 0.049                   | 11.534             | 0.941        |

| Final value   | 250.35  | 0.049   | 11.53   | 0.941  |
|---|---------|---------|---------|--------|
| Instrument impedance correction (N4)                                  | 0.000   | 0.00024 | 0.0576  |        |
| Calibration correction (see Newton 4th calibration report 2020002794) | 1.00025 | 0.99958 | 1.00010 | 1.0000 |
| Max   | 250.480 | 0.049   | 11.537  | 0.941  |
| Min   | 250.039 | 0.049   | 11.530  | 0.940  |
|   | 250.250 | 0.015   | 11.551  | 0.511  |

| Sample 3  | Supply<br>Voltage<br>(Vrms) | Input Current<br>(Arms) | Input Power<br>(W) | Power Factor |
|---|-----------------------------|-------------------------|--------------------|--------------|
| Average   | 250.285                     | 0.049                   | 11.468             | 0.936        |
| Min   | 250.109                     | 0.049                   | 11.464             | 0.935        |
| Max   | 250.430                     | 0.049                   | 11.470             | 0.936        |
| Calibration correction (see Newton 4th calibration report 2020002794) | 1.00025                     | 0.99958                 | 1.00010            | 1.0000       |
| Instrument impedance correction (N4)                                  | 0.000                       | 0.00024                 | 0.0576             |              |
| Final value   | 250.35                      | 0.049                   | 11.47              | 0.936        |

The he tests and measurements covered by this document are traceable to Australian national standards of measurement.

This report only applies to the items tested as received from the client and shall only be reproduced in full unless approved in writing by Light Emission Distribution Laboratory (LEDLab).



# Test Report: 230140LCP

| Sample 4  | Supply<br>Voltage<br>(Vrms) | Input Current<br>(Arms) | Input Power<br>(W) | Power Factor |
|---|-----------------------------|-------------------------|--------------------|--------------|
| Average   | 250.273                     | 0.049                   | 11.473             | 0.939        |
| Min   | 250.059                     | 0.049                   | 11.470             | 0.938        |
| Max   | 250.480                     | 0.049                   | 11.476             | 0.939        |
| Calibration correction (see Newton 4th calibration report 2020002794) | 1.00025                     | 0.99958                 | 1.00010            | 1.0000       |
| Instrument impedance correction (N4)                                  | 0.000                       | 0.00024                 | 0.0576             |              |
| Final value   | 250.33                      | 0.049                   | 11.47              | 0.939        |

| Sample 5  | Supply<br>Voltage<br>(Vrms) | Input Current<br>(Arms) | Input Power<br>(W) | Power Factor |
|---|-----------------------------|-------------------------|--------------------|--------------|
| Average   | 250.268                     | 0.049                   | 11.509             | 0.936        |
| Min   | 250.149                     | 0.049                   | 11.504             | 0.935        |
| Max   | 250.460                     | 0.049                   | 11.511             | 0.936        |
| Calibration correction (see Newton 4th calibration report 2020002794) | 1.00025                     | 0.99958                 | 1.00010            | 1.0000       |
| Instrument impedance correction (N4)                                  | 0.000                       | 0.00024                 | 0.0576             |              |
| Final value   | 250.33                      | 0.049                   | 11.51              | 0.936        |

| Sample 6  | Supply<br>Voltage<br>(Vrms) | Input Current<br>(Arms) | Input Power<br>(W) | Power Factor |
|---|-----------------------------|-------------------------|--------------------|--------------|
| Average   | 250.264                     | 0.049                   | 11.444             | 0.939        |
| Min   | 250.099                     | 0.049                   | 11.441             | 0.938        |
| Max   | 250.710                     | 0.049                   | 11.451             | 0.939        |
|   |                             |                         |                    |              |
| Calibration correction (see Newton 4th calibration report 2020002794) | 1.00025                     | 0.99958                 | 1.00010            | 1.0000       |
| Instrument impedance correction (N4)                                  | 0.000                       | 0.00024                 | 0.0576             |              |
| Final value   | 250.33                      | 0.049                   | 11.45              | 0.939        |

| Sample 7  | Supply<br>Voltage<br>(Vrms) | Input Current<br>(Arms) | Input Power<br>(W) | Power Factor |
|---|-----------------------------|-------------------------|--------------------|--------------|
| Average   | 250.277                     | 0.050                   | 11.632             | 0.939        |
| Min   | 250.079                     | 0.049                   | 11.628             | 0.939        |
| Max   | 250.470                     | 0.050                   | 11.635             | 0.940        |
| Calibration correction (see Newton 4th calibration report 2020002794) | 1.00025                     | 0.99958                 | 1.00010            | 1.0000       |
| Instrument impedance correction (N4)                                  | 0.000                       | 0.00024                 | 0.0576             |              |
| Final value   | 250.34                      | 0.049                   | 11.63              | 0.939        |



# Test Report: 230140LCP

| Sample 8  | Supply<br>Voltage<br>(Vrms) | Input Current<br>(Arms) | Input Power<br>(W) | Power Factor |
|---|-----------------------------|-------------------------|--------------------|--------------|
| Average   | 250.238                     | 0.049                   | 11.432             | 0.937        |
| Min   | 250.109                     | 0.049                   | 11.429             | 0.936        |
| Max   | 250.330                     | 0.049                   | 11.435             | 0.937        |
| Calibration correction (see Newton 4th calibration report 2020002794) | 1.00025                     | 0.99958                 | 1.00010            | 1.0000       |
| Instrument impedance correction (N4)                                  | 0.000                       | 0.00024                 | 0.0576             |              |
| Final value   | 250.30                      | 0.049                   | 11.43              | 0.937        |

| Sample 9  | Supply<br>Voltage<br>(Vrms) | Input Current<br>(Arms) | Input Power<br>(W) | Power Factor |
|---|-----------------------------|-------------------------|--------------------|--------------|
| Average   | 250.205                     | 0.048                   | 11.329             | 0.936        |
| Min   | 249.939                     | 0.048                   | 11.326             | 0.936        |
| Max   | 250.340                     | 0.048                   | 11.334             | 0.936        |
| Calibration correction (see Newton 4th calibration report 2020002794) | 1.00025                     | 0.99958                 | 1.00010            | 1.0000       |
| Instrument impedance correction (N4)                                  | 0.000                       | 0.00024                 | 0.0576             |              |
| Final value   | 250.27                      | 0.048                   | 11.33              | 0.936        |

| Sample 10   | Supply<br>Voltage<br>(Vrms) | Input Current<br>(Arms) | Input Power<br>(W) | Power Factor |
|---|-----------------------------|-------------------------|--------------------|--------------|
| Average   | 250.143                     | 0.049                   | 11.455             | 0.939        |
| Min   | 249.899                     | 0.049                   | 11.450             | 0.939        |
| Max   | 250.350                     | 0.049                   | 11.460             | 0.939        |
| Calibration correction (see Newton 4th calibration report 2020002794) | 1.00025                     | 0.99958                 | 1.00010            | 1.0000       |
| Instrument impedance correction (N4)                                  | 0.000                       | 0.00024                 | 0.0576             |              |
| Final value   | 250.20                      | 0.049                   | 11.46              | 0.939        |



Table 1. Electrical operating parameters of StreetLED3 LED 11W 4K SPD FTB D

| Sample No. | Supply Voltage<br>(Vrms) | Input Current<br>(Arms) | Input Power (W) | Power Factor |
|------------|--------------------------|-------------------------|-----------------|--------------|
| Sample 1   | 250.34                   | 0.049                   | 11.36           | 0.935        |
| Sample 2   | 250.35                   | 0.049                   | 11.53           | 0.941        |
| Sample 3   | 250.35                   | 0.049                   | 11.47           | 0.936        |
| Sample 4   | 250.33                   | 0.049                   | 11.47           | 0.939        |
| Sample 5   | 250.33                   | 0.049                   | 11.51           | 0.936        |
| Sample 6   | 250.33                   | 0.049                   | 11.45           | 0.939        |
| Sample 7   | 250.34                   | 0.049                   | 11.63           | 0.939        |
| Sample 8   | 250.30                   | 0.049                   | 11.43           | 0.937        |
| Sample 9   | 250.27                   | 0.048                   | 11.33           | 0.936        |
| Sample 10  | 250.20                   | 0.049                   | 11.46           | 0.939        |
| Average    | 250.31                   | 0.049                   | 11.46           | 0.938        |

## Uncertainties

At a Confidence Level of 95% with a Coverage Factor of 2:

Supply Voltage: ± 0.07% Supply Current: ± 0.14% Supply Power: ± 0.19% Power Factor: ± 0.005 Ambient Temperature: ± 1°C

## **Test Equipment Used**

Power meter: Newton 4<sup>th</sup> Power Analyser KinetiQ Model PPA2520 SN 133-00467 Power meter integration time (s): 5 Calibration Report: PlusEs report no. 2020002794 Luminaire thermometer: AMA S No. 1086110-0.1deg

The he tests and measurements covered by this document are traceable to Australian national standards of measurement.

This report only applies to the items tested as received from the client and shall only be reproduced in full unless approved in writing by Light Emission Distribution Laboratory (LEDLab).



## Test Report: 230140LCP

## **General Photographs**



Photo 1. Luminaire.



Photo 2. Luminaire.



Photo 3. LED board.



Photo 4. Gear tray.



Photo 5. LED driver.




Photo 6. Luminaire label.





Photo 7. Luminaire during the test.



Photo 8. Marking.