

# **Victorian Transfer Limit Advice – Outages in Adjacent Regions**

**March 2021**

For the National Electricity Market

---

# Important notice

## **PURPOSE**

AEMO has prepared this document to provide information about voltage and transient stability limits for flows to and from Victoria, as at the date of publication.

## **DISCLAIMER**

This document or the information in it may be subsequently updated or amended. This document does not constitute legal or business advice, and should not be relied on as a substitute for obtaining detailed advice about the National Electricity Law, the National Electricity Rules, or any other applicable laws, procedures or policies. AEMO has made every effort to ensure the quality of the information in this document but cannot guarantee its accuracy or completeness.

Accordingly, to the maximum extent permitted by law, AEMO and its officers, employees and consultants involved in the preparation of this document:

- make no representation or warranty, express or implied, as to the currency, accuracy, reliability or completeness of the information in this document; and
- are not liable (whether by reason of negligence or otherwise) for any statements or representations in this document, or any omissions from it, or for any use or reliance on the information in it.

## VERSION CONTROL

---

Version	Release date	Changes
3	12/03/2021	Update to offsets to Vic to NSW voltage stability export limit from Victoria to NSW for loss of both APD Potlines for outages in NSW
2		Added Stockdill to Upper Tumut outage
1	2/11/2020	Initial version – limits copied from the Vic single outages doc

# Contents

<b>1.</b>	<b>Introduction</b>	<b>6</b>
1.1	Other AEMO publications	6
1.2	Calculating transient and voltage stability limits	6
1.3	Calculating voltage unbalance limits	6
1.4	Calculating voltage oscillation limits	7
1.5	Conversion to Constraint Equations	8
<b>2.</b>	<b>NSW – Single Outages</b>	<b>9</b>
2.1	Balranald to Buronga (X3) 220 kV line	9
2.2	Balranald to Darlington Point (X5) 220 kV line	11
2.3	Canberra to Capital (6) 330 kV line	12
2.4	Canberra to Lower Tumut (7) 330 kV line	12
2.5	Capital to Kangaroo Valley (3W) 330 kV line	12
2.6	Collector to Marulan (4) 330 kV line	14
2.7	Collector to Yass (3L) 330 kV line	15
2.8	Darlington Point to Wagga (63) 330 kV line	16
2.9	Gullen Range to Yass (3J) 330 kV line	17
2.10	Jindera to Wagga (62) 330 kV line	18
2.11	Lower Tumut To Murray (66) 330 kV line	19
2.12	Lower Tumut To Upper Tumut (64) 330 kV line	21
2.13	Lower Tumut to Wagga (051) 330 kV line	22
2.14	Lower Tumut to Yass (3) 330 kV line	24
2.15	Marulan to Yass (5) 330 kV line	25
2.16	Murray To Upper (65) Tumut 330 kV line	26
2.18	Stockdill to Upper Tumut (1) 330 kV line	28
2.19	Upper Tumut to Ravine (6X) 330 kV line	29
<b>3.</b>	<b>South Australia - Single Outages</b>	<b>30</b>
3.1	South East to Taillem Bend 275 kV line	30
<b>A1.</b>	<b>Measures and Definitions</b>	<b>31</b>
	Units of Measure	31
	Parameter Definitions	31
	Glossary	36

# Tables

Table 1	N^V BALR-BSS_BLVG offset	9
Table 2	V^S [MRLK] BALR-BSS_BEKG	10
Table 3	V^N CANB-CAP_BLVG offset	12
Table 4	V^N_2xAPD offset	12
Table 5	V^N_2xAPD offset	12
Table 6	V^N CANB-CAP_BLVG offset	13
Table 7	V^N_2xAPD offset	13
Table 8	V^N_2xAPD offset	14
Table 9	V^N_2xAPD offset	17
Table 10	V^N_2xAPD offset	17
Table 11	V^N GULL-YASS_BLVG offset	17
Table 12	V::N HOTS-RCTS_V/Q/S/S_decel offsets	18
Table 13	V^N JIND-WAGGA_BLVG offset	18
Table 14	V::N LTSS-MSS_V coefficients	19
Table 15	V::N LTSS-MSS_S coefficients	20
Table 16	V::N LTSS-WAGGA_V/Q/S/S_decel offsets	22
Table 17	V^N LTSS-WAGGA BLVG coefficients	23
Table 18	V^N LTSS-YASS_BLVG offset	24
Table 19	V^N_2xAPD offset	26
Table 20	V^N MSS-UTSS_BLVG offsets	26
Table 21	V^N_2xAPD offset	29
Table 22	V::N SESS-TAIL_V/Q/S/S_decel offsets	30

# 1. Introduction

AEMO is responsible for calculating the maximum transient and voltage stability limits into and out of Victoria, voltage oscillation limits due to low system strength, as well as voltage unbalance constraints to keep the system within specified limits, in accordance with the National Electricity Rules (NER) S5.1.2.3 and the Power System Stability Guidelines<sup>1</sup>. This document describes the values for these transfer limits for single and multiple prior outage conditions in NSW and South Australia.

This limits advice document also describes the methodology used by AEMO to determine the transient and voltage stability limits, voltage oscillation and the voltage unbalance limits.

The limit equations for system normal cases are described in a separate document, *Victorian Transfer Limit Advice – System Normal*. Limit equations for single and multiple prior outages are described in *Victorian Transfer Limit Advice – Outages* and *Victorian Transfer Limit Advice – Multiple Outages*. These documents are available on the AEMO website<sup>2</sup>.

## 1.1 Other AEMO publications

Other limit advice documents are located at: <https://www.aemo.com.au/energy-systems/electricity/national-electricity-market-nem/system-operations/congestion-information-resource/limits-advice>

## 1.2 Calculating transient and voltage stability limits

Transfer limit equations are developed for power transfers into and out of Victoria (known as import and export limits respectively). Maximum export is limited by transient stability, whereas maximum import is determined by voltage stability.

Transient stability limit equations are derived from a large number of transient stability studies. Stability studies are based on the application of a 2-phase to ground fault at the most critical fault location.

Voltage stability limit equations are derived from a large number of load flow studies. Studies consider the trip of a large generator, the loss of Basslink when exporting from Tasmania (Tas.) to Victoria (Vic.), and where appropriate the fault and trip of a critical transmission line or transformer.

### 1.2.1 Methodology

The methodology for calculating voltage and transient stability limits is given below:

1. Generate a set of Power System Simulator for Engineering (PSS/E) cases to represent a wide range of operating conditions.
2. Execute a binary search algorithm to search for limiting interconnector power transfer.
3. Linear regression and statistical limit determination.

## 1.3 Calculating voltage unbalance limits

Voltage unbalance is based on the levels of negative sequence voltage. As specified in S5.1a.1 of the NER, the negative sequence voltage needs to be limited to 0.5% of nominal voltage for busbars greater than 100 kV. With the introduction of generation in the southwest of Victoria, AEMO has determined that under specific

---

<sup>1</sup> AEMO, *Power System Stability Guidelines*, Available at: <http://www.aemo.com.au/Electricity/National-Electricity-Market-NEM/Security-and-reliability/Congestion-information>, Viewed on 31 August 2016.

<sup>2</sup> Available at: <https://www.aemo.com.au/energy-systems/electricity/national-electricity-market-nem/system-operations/congestion-information-resource/limits-advice>

outage conditions, the voltage unbalance at the Portland smelter (APD) 500 kV busbar can exceed these levels.

The limit equations are defined such that the simulated negative sequence voltage on the APD 500 kV bus does not exceed 0.4 % of nominal voltage<sup>3</sup> for system normal and prior circuit outage conditions. This allows for a margin of 0.1%, which is considered a minimum requirement to account for the following:

- Other sources of unbalance, including effect of loads and generation that were not represented. The simulation results only represent unbalance associated with the transmission network.
- Sufficient measurements of voltage unbalance in the APD area that are not presently available to enable verification or calibration of the simulation model.

As well, the maximum simulated voltage unbalance at APD without the additional generation in the south west of Victoria is 0.4%.

The voltage unbalance levels at APD are influenced by a combination of:

- Voltage balancing effect (or reduction of negative sequence voltage) at Mortlake caused by the Mortlake generators.
- Power flow and associated negative sequence voltage across the Mortlake (MOPS) to Moorabool (MLTS), and Mortlake (MOPS) to Heywood (HYTS) to APD No. 2 500 kV lines (which are not fully transposed).
- Power flow on the Moorabool (MLTS) to Tarrone (TRTS) to Heywood (HYTS) to APD No. 1 500 kV line and mutual coupling with the MOPS-MLTS and MOPS-HYTS-APD No. 2 500 kV lines.

These factors can produce additive or counteractive effects on negative sequence voltage at APD, depending on the direction of power flow in the MOPS-MLTS and MOPS-HYTS-APD No. 2 500 kV lines and adjacent MLTS-TRTS-HYTS-APD No. 1 500 kV line.

### 1.3.1 Methodology

A number of voltage unbalance simulations were performed using a Power Systems Computer Aided Design (PSCAD) model of the 500 kV network. From these results, limit equations were produced to keep the level of voltage unbalance at APD at or below 0.4% during specific outages on the 500 kV network. These equations quantify the relationship between generation, Vic to SA transfer (via Heywood), and where relevant, APD load, such that the simulated voltage unbalance at APD will not exceed 0.4%.

It is assumed that the net APD load can vary between 405 MW to 615 MW, and Portland wind farm can generate up to 100 MW.

## 1.4 Calculating voltage oscillation limits

Voltage oscillations and associated instability can occur in parts of the power system that have low system strength, especially during prior outage conditions. To mitigate such oscillations in Western Victoria power system, voltage oscillatory stability limits are determined for low system strength conditions including prior outage conditions. Simulations of large disturbances such as two-phase to ground fault and trip of critical lines are undertaken using PSCAD to determine if the voltage oscillations occur in the power system post-contingency.

Large disturbance simulations of several operating conditions are undertaken to determine the limiting operating conditions of the power system which prevent voltage oscillations from occurring.

### 1.4.1 Methodology

Voltage oscillation stability limits were determined by performing electromagnetic-transient simulations using PSCAD on a model of the north-west Victorian and south-west NSW networks. Several possible power system

---

<sup>3</sup> Line to Line = 2 kV and Line to Neutral = 1.15 kV

scenarios including Murraylink power import and export conditions, wind farm and solar farm operating conditions, battery operating conditions and special protection schemes were considered in the simulations.

## 1.5 Conversion to Constraint Equations

This document does not describe how AEMO implements these limit equations as constraint equations in the National Electricity Market (NEM) market systems. That is covered in the Constraint Formulation Guidelines, Constraint Naming Guidelines and Constraint Implementation Guidelines. These documents are located in the Congestion Information Resource on the AEMO website:

<https://www.aemo.com.au/energy-systems/electricity/national-electricity-market-nem/system-operations/congestion-information-resource>



# 2. NSW – Single Outages

Note: these limits are in addition to the limits provided by TransGrid for each of these outages.

## 2.1 Balranald to Buronga (X3) 220 kV line

The following limit equations are enabled during an outage of the Balranald to Buronga (X3) 220 kV line.

### 2.1.1 Voltage Stability – NSW to Vic

#### **Largest Vic generator or Basslink trip**

To manage the Victorian voltage stability import limit from NSW to Victoria for fault and trip of Basslink or the loss of the largest Victorian generator, apply the following prior outage offset to the system normal equation NIL\_VI\_BLVG. Studies monitored post-contingent voltages and reactive power margin in northern Victoria and southern NSW. The limit equation is of the form:

$$NSW\ to\ Victoria \leq [-1 * Sum [Term\ Values * System\ Normal\ Coefficients] ] + Offset$$

**Table 1** NAV BALR-BSS\_BLVG offset

Term	Offset
Offset to system normal equation NIL_VI_BLVG	-60

#### **Dederang to Murray 330 kV line trip**

The system normal voltage stability equation NIL\_VI\_BLVG will manage voltage stability associated with the loss of a Dederang to Murray 330 kV line. Therefore, no additional offset is required.

### 2.1.2 Voltage Stability - Murraylink

To manage the Murraylink voltage stability export limit from Victoria to SA for fault and trip of the Bendigo to Kerang 220 kV line, apply the following prior outage limit equations. Studies assume the Red Cliffs Voltage source controller (VSC) is in voltage control mode with the Very Fast Runback (VFRB) scheme disabled. Studies monitored post-contingent voltages and reactive power margin in southern NSW and the Victorian state grid. The limit equation is of the form:

$$Victoria\ to\ SA\ (Murraylink) \leq Sum [Term\ Values * Coefficients]$$

**Table 2 VAS [MRLK] BALR-BSS\_BEKG**

Term	Coefficient
Intercept	242.8
RCTS Load	-1.242
KGTS Load	-1.939
BKNH TX MW	-0.9566
HOTS SVC Out of Service	-36
Confidence Level (95%) offset	-40

### 2.1.3 Voltage Oscillation

To prevent voltage oscillations for the trip of Ararat to Waubra to Ballarat or Bendigo to Kerang 220 kV line the following limits are applied:

*Bannerton solar farm  $\leq 45$  MW*

*Bulgana wind farm  $\leq 0$  MW (can be operated in 'Pause Mode')*

*Bulgana battery = 0 MW with all inverters disconnected.*

*Coleambally solar farm  $\leq 50$  MW*

*Darlington Point solar farm  $\leq 100$  MW*

*Finley solar farm  $\leq 50$  MW*

*Gannawarra solar farm  $\leq 30$  MW*

*Horsham SVC switched off or set to manual mode with a fixed Q setpoint*

*Karadoc solar farm  $\leq 25$  MW*

*Kiamal solar farm  $\leq 50$  MW*

*Murra Warra wind farm  $\leq 90$  MW*

*Murraylink SA-VIC  $\leq 130$  MW*

*Wemen solar farm  $\leq 45$  MW*

*Yatpool solar farm  $\leq 25$  MW*

## 2.2 Balranald to Darlington Point (X5) 220 kV line

The same limits applied for Balranald to Buronga (X3) apply for this outage (refer to section 2.1).

## 2.3 Canberra to Capital (6) 330 kV line

The following limit equations are enabled during an outage of the Canberra to Capital (6) 330 kV line.

### 2.3.1 Voltage Stability – NSW to Vic

To manage the Victorian voltage stability import limit from NSW to Victoria for fault and trip of Basslink or the loss of the largest Victorian generator, apply the following prior outage offset to the system normal equation NIL\_VI\_BLVG. Studies monitored post-contingent voltages and reactive power margin in northern Victoria and southern NSW. The limit equation is of the form:

$$NSW\ to\ Victoria \leq [ -1 * Sum [System\ Normal\ Term\ Values * System\ Normal\ Coefficients] ] + Offset$$

**Table 3 VAN CANB-CAP\_BLVG offset**

Term	Offset
Offset to system normal equation NIL_VI_BLVG	-50

To manage the Vic to NSW voltage stability export limit from Victoria to NSW for loss of both APD Potlines, apply the following prior outage offset to the system normal equation V^N\_2xAPD. The limit equation is of the form:

$$Victoria\ to\ NSW \leq Sum [Term\ Values * Coefficients] + Offset$$

**Table 4 VAN\_2xAPD offset**

Term	Offset
Offset to system normal V^N_2xAPD	-100

## 2.4 Canberra to Lower Tumut (7) 330 kV line

The following limit equation is enabled during an outage of the Marulan to Yass 330 kV line.

### 2.4.1 Voltage Stability – Vic to NSW

To manage the Vic to NSW voltage stability export limit from Victoria to NSW for loss of both APD Potlines, apply the following prior outage offset to the system normal equation V^N\_2xAPD. The limit equation is of the form:

$$Victoria\ to\ NSW \leq Sum [Term\ Values * Coefficients] + Offset$$

**Table 5 VAN\_2xAPD offset**

Term	Offset
Offset to system normal V^N_2xAPD	-75

## 2.5 Capital to Kangaroo Valley (3W) 330 kV line

The following limit equations are enabled during an outage of the Capital to Kangaroo Valley (3W) 330 kV line.

### 2.5.1 Voltage Stability – NSW to Vic

To manage the Victorian voltage stability import limit from NSW to Victoria for fault and trip of Basslink or the loss of the largest Victorian generator, apply the following prior outage offset to the system normal equation NIL\_VI\_BLVG. Studies monitored post-contingent voltages and reactive power margin in northern Victoria and southern NSW. The limit equation is of the form:

$$NSW\ to\ Victoria \leq [ -1 * Sum [System\ Normal\ Term\ Values * System\ Normal\ Coefficients] ] + Offset$$

**Table 6 V^N CANB-CAP\_BLVG offset**

Term	Offset
Offset to system normal equation NIL_VI_BLVG	-50

To manage the Vic to NSW voltage stability export limit from Victoria to NSW for loss of both APD Potlines, apply the following prior outage offset to the system normal equation V^N\_2xAPD. The limit equation is of the form:

$$Victoria\ to\ NSW \leq Sum [Term\ Values * Coefficients] + Offset$$

**Table 7 V^N\_2xAPD offset**

Term	Offset
Offset to system normal V^N_2xAPD	-100

## 2.6 Collector to Marulan (4) 330 kV line

The following limit equation is enabled during an outage of the Marulan to Yass 330 kV line.

### 2.6.1 Voltage Stability – Vic to NSW

To manage the Vic to NSW voltage stability export limit from Victoria to NSW for loss of both APD Potlines, apply the following prior outage offset to the system normal equation  $V^N_{2xAPD}$ . The limit equation is of the form:

$$\text{Victoria to NSW} \leq \text{Sum [Term Values * Coefficients]} + \text{Offset}$$

**Table 8**  $V^N_{2xAPD}$  offset

Term	Offset
Offset to system normal $V^N_{2xAPD}$	-100

## 2.7 Collector to Yass (3L) 330 kV line

The same limits applied for Collector to Marulan (4) apply for this outage (refer to section 2.6).

## 2.8 Darlington Point to Wagga (63) 330 kV line

The following limits are enabled during an outage of the Darlington Point to Wagga (63) 330 kV line.

### 2.8.1 Voltage Oscillation

To prevent voltage oscillations for the trip of the Ararat to Waubra to Ballarat or Bendigo to Kerang 220 kV line the following limits are applied:

#### **When the line X5 (Balranald-Darlington Point) is opened.**

*Bannerton solar farm  $\leq 45$  MW*

*Bulgana wind farm  $\leq 0$  MW (can be operated in 'Pause Mode')*

*Bulgana battery = 0 MW with all inverters disconnected.*

*Coleambally solar farm  $\leq 50$  MW*

*Finley solar farm  $\leq 50$  MW*

*Gannawarra solar farm  $\leq 30$  MW*

*Horsham SVC switched off or set to manual mode with a fixed Q setpoint*

*Karadoc solar farm  $\leq 25$  MW*

*Kiamal solar farm  $\leq 50$  MW*

*Murra Warra wind farm  $\leq 90$  MW*

*Murraylink SA-VIC  $\leq 130$  MW*

*Wemen solar farm  $\leq 45$  MW*

*Yatpool solar farm  $\leq 25$  MW*

#### **When the line X5 (Balranald-Darlington Point) is in service.**

*Bannerton solar farm  $\leq 45$  MW*

*Bulgana wind farm  $\leq 0$  MW (can be operated in 'Pause Mode')*

*Bulgana battery = 0 MW with all inverters disconnected.*

*Gannawarra solar farm  $\leq 30$  MW*

*Horsham SVC switched off or set to manual mode with a fixed Q setpoint*

*Karadoc solar farm  $\leq 25$  MW*

*Kiamal solar farm  $\leq 50$  MW*

*Murra Warra wind farm  $\leq 90$  MW*

*Murraylink SA-VIC  $\leq 130$  MW*

*Wemen solar farm  $\leq 45$  MW*

*Yatpool solar farm  $\leq 25$  MW*



## 2.8.2 Voltage Stability – Vic to NSW

To manage the Vic to NSW voltage stability export limit from Victoria to NSW for loss of both APD Potlines, apply the following prior outage offset to the system normal equation  $V^N_{2xAPD}$ . The limit equation is of the form:

$$\text{Victoria to NSW} \leq \text{Sum [Term Values * Coefficients]} + \text{Offset}$$

**Table 9 VAN\_2xAPD offset**

Term	Offset
Offset to system normal $V^N_{2xAPD}$	-100

For Darlington Point to Wagga (63) 330 kV line outage, if X5 (Balranald to Darlington Point 220 kV) is also out of service the limit equation is of the form following:

$$\text{Victoria to NSW} \leq \text{Sum [Term Values * Coefficients]} + \text{Offset}$$

**Table 10 VAN\_2xAPD offset**

Term	Offset
Offset to system normal $V^N_{2xAPD}$	-200

## 2.9 Gullen Range to Yass (3J) 330 kV line

The following limit equations are enabled during an outage of the Gullen Range to Yass 330 kV line.

### 2.9.1 Voltage Stability – NSW to Vic

To manage the Victorian voltage stability import limit from NSW to Victoria for fault and trip of Basslink or the loss of the largest Victorian generator, apply the following prior outage offset to the system normal equation  $NIL_{VI\_BLVG}$ . Studies monitored post-contingent voltages and reactive power margin in northern Victoria and southern NSW. The limit equation is of the form:

$$\text{NSW to Victoria} \leq [ -1 * \text{Sum [System Normal Term Values * System Normal Coefficients]} ] + \text{Offset}$$

**Table 11 VAN GULL-YASS\_BLVG offset**

Term	Offset
Offset to system normal equation $NIL_{VI\_BLVG}$	-50

## 2.10 Jindera to Wagga (62) 330 kV line

The following limit equations are enabled during an outage of the Jindera to Wagga 330 kV line.

Note : Balranald to Darlington Point (X5) line is also out of service for this outage and the limits for an X5 outage also apply (see section 2.2).

### 2.10.1 Transient Stability – Vic to NSW

To manage the Victorian transient stability export limit from Victoria to NSW for fault and trip of a Hazelwood to South Morang 500 kV line, apply the following prior outage offsets to system normal equations NILV, NILQ, NILS and NILS decelerating. The limit equation is of the form:

$$\text{Victoria to NSW} \leq \text{Sum [Term Values * System Normal Coefficients]} + \text{Offset}$$

**Table 12 V::N HOTS-RCTS\_V/Q/S/S\_decel offsets**

Term	Offset
Offset to system normal equation NILV	-50
Offset to system normal equation NILQ	0
Offset to system normal equation NILS	-50
Offset to system normal equation NILS_decel	-50

### 2.10.2 Voltage Stability – NSW to Vic

#### Largest Vic generator or Basslink trip

To manage the Victorian voltage stability import limit from NSW to Victoria for fault and trip of Basslink or the loss of the largest Victorian generator, apply the following prior outage offset to the system normal equation NIL\_VI\_BLVG. Studies monitored post-contingent voltages and reactive power margin in northern Victoria and southern NSW. The limit equation is of the form:

$$\text{NSW to Victoria} \leq [ -1 * \text{Sum [Term Values * System Normal Coefficients]} ] + \text{Offset}$$

**Table 13 V^N JIND-WAGGA\_BLVG offset**

Term	Offset
Offset to system normal equation NIL_VI_BLVG	-60

#### Dederang to Murray 330 kV line trip

The system normal voltage stability equation NIL\_VI\_BLVG will manage voltage stability associated with the loss of a Dederang to Murray 330 kV line. Therefore no additional offset is required.

### 2.10.3 Voltage Oscillation

To prevent voltage oscillations for the trip of Ararat to Waubra to Ballarat or Bendigo to Kerang 220 kV line the voltage oscillation limits for the Dederang to Wodonga 330 kV are applied (see Vic Transfer Limit Advice – Outages).

## 2.11 Lower Tumut To Murray (66) 330 kV line

The following limit equations are enabled during an outage of the Lower Tumut to Murray 330 kV line.

### 2.11.1 Transient Stability – Vic to NSW

#### V::N LTSS-MSS\_V

To manage the Victorian transient stability export limit from Victoria to NSW for fault and trip of the Murray to Upper Tumut 330 kV line (where Victoria accelerates ahead of the other states), apply the following limit equation:

$$\text{Victoria to NSW} \leq \text{Sum} [\text{Term Values} * \text{Coefficients}]$$

**Table 14 V::N LTSS-MSS\_V coefficients**

Term	Coefficient
Intercept	1013
Basslink	0.07939
Vic. to SA (Heywood)	0.03878
Vic. to SA (Heywood)^2	-1.855e-4
Vic. to SA (Murraylink)	-0.5962
LV 500 Inertia	1.051
EPS Inertia	7.054
SNOWY Inertia	1.862
Murray Gen	0.1849
Kiewa Gen	0.2187
LV 220 Gen	0.1088
VIC Metro Gen	0.1639
State Grid Load North	-0.3499
Vic Wind & Solar	0.05988
VIC Demand - State Grid Load North	-0.05126
220 kV Caps	-0.07045
Num. ROTS SVC	14.09
Confidence Level (95%) offset	-60

#### V::N LTSS-MSS\_S

To manage the Victorian transient stability export limit from Victoria to NSW for fault and trip of the Murray to Upper Tumut 330 kV line (where Victoria accelerates ahead of the other states), apply the following limit equation:

$$\text{Victoria to NSW} \leq \text{Sum} [\text{Term Values} * \text{Coefficients}]$$

**Table 15 V::N LTSS-MSS\_S coefficients**

Term	Coefficient
Intercept	938
Basslink	0.05857
Vic. to SA (Heywood)^2	-1.279e-4
Vic. to SA (Murraylink)	-0.4675
LV 500 Inertia	0.9008
SNOWY Inertia	1.973
VIC METRO Gen Inertia	1.407
Murray Gen	0.1011
Kiewa Gen	0.2234
LV 220 Gen	0.04787
State Grid Load North	-0.1881
Vic Wind & Solar	0.06093
VIC Demand - State Grid Load North	-0.03251
Num. ROTS SVC	13.74
Confidence Level (95%) offset	-68

### 2.11.2 Voltage Stability – NSW to Vic

The system normal voltage stability equation NIL\_VI\_BLVG will manage voltage stability associated with the fault and trip of Basslink, the loss of the largest Victorian generator or the loss of a Murray to Upper Tumut 330 kV line. Therefore no additional offset is required.

## 2.12 Lower Tumut To Upper Tumut (64) 330 kV line

The following limit equations are enabled during an outage of the Lower Tumut to Upper Tumut 330 kV line.

### 2.12.1 Voltage Stability – NSW to Vic

The system normal voltage stability equation NIL\_VI\_BLVG will manage voltage stability associated with the fault and trip of Basslink, the loss of the largest Victorian generator or loss of a Murray to Upper Tumut 330 kV line. Therefore no additional offset is required.

## 2.13 Lower Tumut to Wagga (051) 330 kV line

The following limit equations are enabled during an outage of the Lower Tumut to Wagga 330 kV line.

### 2.13.1 Transient Stability – Vic to NSW

To manage the Victorian transient stability export limit from Victoria to NSW for fault and trip of a Hazelwood to South Morang 500 kV line, apply the following prior outage offsets to system normal equations NILV, NILQ, NILS and NILS decelerating. The limit equation is of the form:

$$\text{Victoria to NSW} \leq \text{Sum [Term Values * System Normal Coefficients]} + \text{Offset}$$

**Table 16 V::N LTSS-WAGGA\_V/Q/S/S\_decel offsets**

Term	Offset
Offset to system normal equation NILV	-30
Offset to system normal equation NILQ	0
Offset to system normal equation NILS	-30
Offset to system normal equation NILS_decel	-30

### 2.13.2 Voltage Stability – NSW to Vic

To manage Victorian voltage stability import limit from NSW to Victoria for fault and trip of Basslink, the loss of the largest Victorian generator or loss of a Dederang to Murray 330 kV line., apply the following limit equation. Studies monitor post-contingent voltages and reactive power margin in northern Victoria and southern NSW. The limit equation is of the form:

$$\text{NSW to Victoria} \leq -1 * \text{Sum [Term Values * Coefficients]}$$

**Table 17 VAN LTSS-WAGGA BLVG coefficients**

<b>Term</b>	<b>Coefficient</b>
Intercept	-1369
Contingent_MW	0.9359
SW_NSW	0.7477
NSWd-SW_NSW	0.008493
STH_NSW_GEN	-0.08801
UTUM1SC+UTUM2SC	-24.27
LTUM3SC	-55.16
MSS2SC	-60.74
DD330Cap	-0.3148
WAGGACap	-0.2354
DLPTShunt	-0.6063
MSSReac	-0.2601
YASSReac	-0.1681
U_TUMUT_Gen	-0.4624
L_TUMUT_Gen	-0.1718
MURRAY_Gen	0.5303
UQT Gen	-0.7286
HUME VIC GEN	-3.360
BKNH_GEN	-1.074
Num. MSS1 on	-18.59
Confidence Level (95%) offset	+83.3

## 2.14 Lower Tumut to Yass (3) 330 kV line

The following limit equations are enabled during an outage of the Lower Tumut to Yass 330 kV line.

### 2.14.1 Voltage Stability – NSW to Vic

To manage the Victorian voltage stability import limit from NSW to Victoria for fault and trip of Basslink or the loss of the largest Victorian generator, apply the following prior outage offset to the system normal equation NIL\_VI\_BLVG. Studies monitored post-contingent voltages and reactive power margin in northern Victoria and southern NSW. The limit equation is of the form:

$$NSW\ to\ Victoria \leq [ -1 * Sum [System\ Normal\ Term\ Values * System\ Normal\ Coefficients] ] + Offset$$

**Table 18** VAN LTSS-YASS\_BLVG offset

Term	Offset
Offset to system normal equation NIL_VI_BLVG	-50



## 2.15 Marulan to Yass (5) 330 kV line

The same limits applied for Collector to Marulan (4) apply for this outage (refer to section 2.6).

## 2.16 Murray To Upper (65) Tumut 330 kV line

The following limit equations are enabled during an outage of the Murray to Upper Tumut 330 kV line.

### 2.16.1 Transient Stability – Vic to NSW

To manage the Victorian transient stability export limit from Victoria to NSW for fault and trip of the Lower Tumut to Murray to 330 kV line (where Victoria accelerates ahead of the other states), apply the limit equations in section (see 0) and (see 0).

### 2.16.2 Voltage Stability – NSW to Vic

#### **Largest Vic generator or Basslink trip**

To manage the Victorian voltage stability import limit from NSW to Victoria for fault and trip of Basslink or the loss of the largest Victorian generator, apply the following prior outage offset to the system normal equation NIL\_VI\_BLVG. Studies monitored post-contingent voltages and reactive power margin in northern Victoria and southern NSW. The limit equation is of the form:

$$NSW\ to\ Victoria \leq [ -1 * Sum [Term\ Values * System\ Normal\ Coefficients] ] + Offset$$

### 2.16.3 Voltage Stability – Vic to NSW

To manage the Vic to NSW voltage stability export limit from Victoria to NSW for loss of both APD Potlines, apply the following prior outage offset to the system normal equation V^N\_2xAPD. The limit equation is of the form:

$$Victoria\ to\ NSW \leq Sum [Term\ Values * Coefficients] + Offset$$

**Table 19 V^N\_2xAPD offset**

Term	Offset
Offset to system normal V^N_2xAPD	-200

**Table 20 V^N MSS-UTSS\_BLVG offsets**

Term	Offset
Offset to system normal equation NILV	-120

#### **Lower Tumut to Murray 330 kV line trip**

The system normal voltage stability equation NIL\_VI\_BLVG will manage voltage stability associated with the loss of a Lower Tumut to Murray 330 kV line. Therefore no additional offset is required.

## 2.17 Ravine to Yass (2) 330 kV line

The following limit equation is enabled during an outage of the Upper Tumut to Yass 330 kV line.

### 2.17.1 Voltage Stability – Vic to NSW

To manage the Vic to NSW voltage stability export limit from Victoria to NSW for loss of both APD Potlines, apply the following prior outage offset to the system normal equation  $V^N_{2xAPD}$ . The limit equation is of the form:

$$\text{Victoria to NSW} \leq \text{Sum} [\text{Term Values} * \text{Coefficients}] + \text{Offset}$$

#### **$V^N_{2xAPD}$ offset**

Term	Offset
Offset to system normal $V^N_{2xAPD}$	-50

## 2.18 Stockdill to Upper Tumut (1) 330 kV line

The same limits applied for Canberra to Capital (6) apply for this outage (refer to section 2.3)

## 2.19 Upper Tumut to Ravine (6X) 330 kV line

The following limit equation is enabled during an outage of the Upper Tumut to Yass 330 kV line.

### 2.19.1 Voltage Stability – Vic to NSW

To manage the Vic to NSW voltage stability export limit from Victoria to NSW for loss of both APD Potlines, apply the following prior outage offset to the system normal equation  $V^N_{2xAPD}$ . The limit equation is of the form:

$$\text{Victoria to NSW} \leq \text{Sum [Term Values * Coefficients]} + \text{Offset}$$

**Table 21**  $V^N_{2xAPD}$  offset

Term	Offset
Offset to system normal $V^N_{2xAPD}$	-50

# 3. South Australia - Single Outages

Note: these limits are in addition to the limits provided by ElectraNet for each of these outages.

## 3.1 South East to Tailem Bend 275 kV line

The following limit equations are enabled during an outage of one South East to Tailem Bend 275 kV line.

### 3.1.1 Transient Stability – Vic to NSW

To manage the Victorian transient stability export limit from Victoria to NSW for fault and trip of a Hazelwood to South Morang 500 kV line, apply the following prior outage offsets to system normal equations NILV, NILQ, NILS and NILS decelerating. The limit equation is of the form:

$$\text{Victoria to NSW} \leq \text{Sum [Term Values * System Normal Coefficients]} + \text{Offset}$$

**Table 22** V::N SESS-TAIL\_V/Q/S/S\_decel offsets

Term	Offset
Offset to system normal equation NILV	-50
Offset to system normal equation NILQ	0
Offset to system normal equation NILS	-50
Offset to system normal equation NILS_decel	-50

# A1. Measures and Definitions

## Units of Measure

Abbreviation	Unit of measure
<b>kV</b>	Kilovolt
<b>MVA</b>	Megavolt amperes
<b>MVAR</b>	Megavolt amperes reactive
<b>MW</b>	A Megawatt (MW) is one million watts. A watt (W) is a measure of power and is defined as one joule per second and it measures the rate of energy conversion or transfer.
<b>MW.sec</b>	Megawatt seconds – a measure of the inertia of a generating unit.

## Parameter Definitions

Abbreviation	Definition
<b>220 kV Caps</b>	MVAR output from capacitors connected at 220 kV busbars (i.e. Altona, Brooklyn, Dederang, Fishermans Bend, Keilor, Moorabool, Rowville, Ringwood, Templestowe and Thomastown)
<b>APD-HYTS_MVAR</b>	Alcoa Portland smelter (APD) reactive power export (measured at 500 kV feeders). A negative value indicates that APD is importing MVAR.
<b>APD-HYTS_MW</b>	APD real power export (measured at 500 kV feeders). A negative value indicates that APD is importing MW).
<b>APD Load</b>	APD MW load at 33 kV and 22 kV
<b>APD Net Load</b>	Net load measured at APD 500kV bus (Actual APD load consumption – Portland wind farm generation)
<b>BANReac</b>	MVAR output of Bannaby reactors. Values associated with this term are negative.
<b>Basslink</b>	MW flow on the Basslink interconnector (measured at the receiving end)
<b>BATS TX MW</b>	MW flow through 220/66kV transformers at Ballarat (measured at HV side, positive value indicates load MW)
<b>BETS Load</b>	Bendigo (BETS) customer load (MW)
<b>BHSS220 Load</b>	Broken Hill 220 kV MW industrial (mine) load
<b>BKNH GEN</b>	MW output from Broken Hill Generation

Abbreviation	Definition
<b>BKNH TX MW</b>	MW flow through 220/22kV transformers at Broken Hill (measured at HV side, positive value indicates load MW)
<b>BOPS+MKPS GEN</b>	MW output from Bogong and McKay Power Station [BOPS & MKPS].
<b>Both TAIL-SESS Series Caps Out</b>	Both Tailem Bend – South East series caps out of service (1= Both series caps are out of service)
<b>BRGAsht</b>	MVAR output of Buronga shunt devices. Values associated with this term can be positive or negative
<b>CANCap</b>	MVAR output of Canberra 220 kV capacitor banks. Values associated with this term are positive.
<b>CMACap</b>	MVAR output of Cooma capacitor banks. Values associated with this term are positive.
<b>Constraint equation</b>	These are the mathematical representations that AEMO uses to model power system limitations and FCAS requirements in National Electricity Market Dispatch Engine (NEMDE).
<b>Contingent MW</b>	Maximum of: <ul style="list-style-type: none"> <li>a) MW Transfer from Tas to Vic via Basslink (measured at Loy Yang). Values associated with this term are positive for flows from Tas to Vic.</li> <li>b) MW output of a single generating unit in Vic (MW associated with the contingency: Loss of the Largest Generator). Values associated with this term are positive.</li> </ul>
<b>CUECap</b>	MVAR output of Queanbeyan capacitor banks. Values associated with this term are positive.
<b>DD220Cap</b>	MVAR output of Dederang 220 kV capacitor banks. Values associated with this term are positive.
<b>DD330Cap</b>	MVAR output of Dederang 330 kV capacitor banks. Values associated with this term are positive.
<b>DLPTshunt</b>	MVAR output of Darlington Point shunt devices. Values associated with this term can be positive or negative
<b>DPS GEN</b>	MW output from Dartmouth Power Station [DPS].
<b>EPS Inertia</b>	Inertia from Eildon Power Station (EPS). Inertia is on a 100 MVA base (MW.sec / 100 MVA) as per EMS.
<b>GEN EPS on</b>	Number of Eildon Power station (EPS) units online.
<b>GEN DPS on</b>	Number of Dartmouth Power station units online [DPS].
<b>GEN BOPS on</b>	Number of Bogong Power station units online [BOPS].
<b>GEN MKPS on</b>	Number of McKay Power station units online [MKPS].
<b>GEN WKPS on</b>	Number of West Kiewa Power station units online [WKPS].
<b>Guthega GEN</b>	MW output from Guthega Power Station [GGA].
<b>Guthega Inertia</b>	Inertia from Guthega Power Station [GGA]. Inertia is on a 100 MVA base (MW.sec / 100 MVA) as per EMS.
<b>HOTS Load</b>	Horsham (HOTS) customer load (MW)
<b>HOTS SVC out of service</b>	Horsham SVC out of service, This term is equal to 0 when the SVC is in service, and equal to 1 when the SVC is out of service.
<b>HUME VIC GEN</b>	MW output from Hume Power station (Victorian connection)
<b>HYTS_CAP_Status</b>	Heywood capacitor status (1 = capacitor in service).
<b>JBE Pump</b>	MW at Jindabyne Power Station [JBE]. Values associated with this term are negative.



Abbreviation	Definition
<b>KGTS Load</b>	Kerang (KGTS) customer load (MW)
<b>KGTS SVC out of service</b>	Kerang SVC out of service, This term is equal to 0 when the SVC is in service, and equal to 1 when the SVC is out of service.
<b>Kiewa Gen</b>	MW output from Kiewa hydro scheme generators (Bogong, Clover, Dartmouth, Mckay and West Kiewa).
<b>Kiewa Inertia</b>	Inertia from Kiewa hydro scheme generators (Bogong, Clover, Dartmouth, McKay and West Kiewa). Inertia is on a 100 MVA base (MW.sec / 100 MVA).
<b>L_TUMUT_Gen</b>	MW output from Lower Tumut 3 power station (LTSS). Values associated with this term can be positive or negative due to the ability of Lower Tumut units to operate in pumping mode
<b>LTUM3SC</b>	Number of generator units operating as synchronous condensers at Lower Tumut.
<b>LV 220 Gen</b>	MW output from Latrobe Valley generation on the 220 kV network (Yallourn W2, 3, and 4, and Yallourn unit 1 when connected to the 220 kV network).
<b>LV 220 Inertia</b>	Inertia associated with Latrobe Valley generation on the 220 kV network (Yallourn W2, 3, and 4, and Yallourn unit 1 when connected to the 220 kV network).
<b>LV 500 Inertia</b>	Inertia associated with Latrobe Valley generation on the 500 kV network (Loy Yang (A, B, and Valley Power), Jeeralang, Bairnsdale, and Yallourn W unit 1 when connected to the 500 kV network).
<b>MCAR_Gen</b>	MW output from the Macarthur Wind Farm (MCAR).
<b>MLTS_220_Reactors</b>	Count of MLTS 220 kV reactors.
<b>MLTS_Line_Reactors</b>	Count of MLTS line reactors (2=both reactors in service).
<b>MMWF_Gen</b>	MW output from the Mount Mercer Wind Farm (MMWF).
<b>MOPS Inertia</b>	Inertia from Mortlake Power Station (MOPS). Inertia is on a 100 MVA base (MW.sec / 100 MVA) as per EMS.
<b>MSS2SC</b>	Number of generator units operating as synchronous condensers at Murray 2.
<b>MSSReac</b>	MVAR output of Murray reactors. Values associated with this term are negative.
<b>Murray Gen</b>	MW output from Murray Power Station (Murray 1 and Murray 2).
<b>Num. MSS1 on</b>	Number of generator units operating at Murray 1.
<b>Num. ROTS SVC</b>	Number of Static Var Compensators (SVCs) at Rowville in service.
<b>Num. SESS SVC</b>	Number of SVCs at South East in service.
<b>NSW_D</b>	New South Wales demand
<b>NSWd- SW_NSW</b>	NSW demand (customer load + losses) minus the load in southern NSW.
<b>NSW_H</b>	Inertia of New South Wales generators excluding Murray, Lower Tumut and Upper Tumut (Eraring, Vales Point, Bayswater, Munmorah, Redbank, Mt Piper, Liddell, Bendeela, Kangaroo Valley, Colongra, Tallawarra, Uranquinty)
<b>Parallel System</b>	Victorian system operating in "Parallel" mode, This term is equal to 0 when operating in radial mode, and equal to 1 when operating in parallel mode.
<b>Portland WF</b>	Portland wind farm generation, MW

Abbreviation	Definition
<b>QLD_H</b>	Inertia of Queensland generators (Swanbank B, Gladstone, Tarong, Wivenhoe, Callide B, Stanwell, Callide C, Tarong North, Swanbank E, Barcaldine, Barron Gorge, Callide A, Collinsville, Invicta, Kareeya, Mackay, Mt Stuart, Townsville, Oakey, Millmerran, Braemar, Darling Downs, Condamine, Braemar 2, Kogan Creek)
<b>RCTS Load</b>	Red Cliffs (RCTS) customer load (MW)
<b>Rowville SVC1 or SVC2 out of service</b>	Rowville SVC out of service, This term is equal to 0 when the SVC is in service, and equal to 1 when one SVC is out of service.
<b>SNOWY Inertia</b>	Inertia from the Snowy area (Murray, Lower Tumut and Upper Tumut). Inertia is on a 100 MVA base (MW.sec / 100 MVA).
<b>SNOWY_GSC_H</b>	Inertia of Snowy generation (Murray, Guthega, Lower Tumut and Upper Tumut) minus the inertia of Lower Tumut machines running as pumps. Inertia is on a 100 MVA base (i.e. MW.sec / 100 MVA).
<b>State Grid Load</b>	Vic State Grid Load. This is the sum of the State Grid Load North (SGLN) and State Grid Load South (SGLS).
<b>State Grid Load North</b>	Vic State Grid Load north is the sum of load at the following bulk supply points: Bendigo (BETS), Fosterville (FVTS), Glenrowan (GNTS), Kerang (KGTS), Mt Beauty (MBTS), Red Cliffs (RCTS), Shepparton (SHTS), Wemen (WETS), and Wodonga (WOTS)
<b>State Grid Load South</b>	Vic State Grid Load south is the sum of load at the following bulk supply points: Ararat (ARTS), Ballarat (BATS), Horsham (HOTS), Stawell (STA) and Terang (TGTS).
<b>SW_NSW</b>	Load in Southern NSW is the sum of customer load at the following bulk supply points: Broken Hill (BKH_S1-22 and BKH-220), Gadara (GAD-11), Jounama (JOU-66), Darlington Point (DLP-132), Morven (MOR-132), Albury (ALB-132), AMN-132, Coleambally (CLY-132), Marulan (MRN-132, GOU-132), Wagga (WAN-132, WAN-66, WAW-132), Murrumburrah (MRU-66), Deniliquin (DNQ-66), Yass (YAS-66), Balranald (BRD-22), Finley (FNY-132), Griffith (GRF-132), Mulwala (MUL-132), Corowa (COR-132), and Yanco (YNC-33)
<b>STH_NSW_GEN</b>	Generation in southern NSW. Values associated with this term are positive. Generation in this region are Gullen Range WF, Gullen SF, Capital WF, Cullerin Range WF, Coleambally SF, Gunning WF, Boco Rock WF, Taralga WF, Woodlawn WF, Burrinjuck Hydro, Blowering Hydro, Gadara, and Jounama Hydro Embedded generation
<b>System normal</b>	The configuration of the power system where: <ul style="list-style-type: none"> <li>a) All transmission elements are in service, or</li> <li>b) The network is operating in its normal network configuration.</li> </ul>
<b>TNSP</b>	Transmission Network Service Provider
<b>Tumut Pump</b>	MW of Lower Tumut machines in pumping mode (this MW value is negative).
<b>UQT Gen</b>	MW output from Uranquinty (UQT) Power Station.
<b>U_TUMUT_Gen</b>	MW output from Upper Tumut 1 and Upper Tumut 2 Power Station (UTSS).
<b>UTUM1SC+UTUM2SC</b>	Number of generator units operating as synchronous condensers at Upper Tumut 1 and Upper Tumut 2.
<b>V_MLTS5</b>	MLTS 500 kV voltage (typical values between 450 and 550 kV).
<b>V_MSS3330</b>	Voltage (kV) at the Murray Power Station 330 kV bus.
<b>VIC220_Gen</b>	MW output from Latrobe Valley generation on the 220 kV network (Yallourn W units 2, 3 and 4 and unit 1 when connected to 220 kV network).
<b>Vic Demand</b>	Vic MW demand (calculated as generation minus export).
<b>Vic to SA (Heywood)</b>	MW transfer from Vic to SA via Heywood (measured at South East end). The interconnector direction and lines it consists of follow the NEM standard.

<b>Abbreviation</b>	<b>Definition</b>
<b>Vic to SA (Murraylink)</b>	MW transfer from Vic to SA via Murraylink (measured at Red Cliffs end).
<b>VIC to NSW</b>	MW transfer from Vic to NSW
<b>Vic Demand - State Grid Load</b>	Vic Demand (MW) minus Vic State Grid Load (SGL).
<b>Vic Demand - State Grid Load North – APD Load</b>	Vic Demand (MW) minus Vic State Grid Load North (SGLN) minus APD Load.
<b>Vic Metro Gen</b>	MW output from Vic metropolitan generators (Newport, Somerton, and Laverton North).
<b>Vic Metro Gen Inertia</b>	Inertia from Vic metropolitan generators (Newport, Somerton and Laverton North). Inertia is on a 100 MVA base (MW.sec / 100 MVA) as per EMS.
<b>Vic Wind &amp; Solar</b>	MW Generation from all Vic windfarms and solar plant. This includes Ararat WF, Bald Hills WF, Ballarat Battery (Gen Component), Bannerton SF, Bulgana WF, Chalcum Hills WF, Crowlands WF, Gannawarra Battery (Gen component), Gannawarra SF, Karadoc SF, Kiata WF, Macarthur WF, Moorabool WF, Mortons Lane WF, Mount Gelibrand WF, Mount Mercer WF, Murra Warra WF, Numerkah SF, Oaklands Hill WF, Portland WF, Salt Creek WF, Waubra WF, Wemen SF, Yaloak South WF, Yambuk WF, Yatpool SF and Yendon SF
<b>WAGGACap</b>	MVAR output of Wagga Wagga capacitor banks. Values associated with this term are positive.
<b>WKPS GEN</b>	MW output from West Kiewa Power Station [WKPS].
<b>WETS Load</b>	Wemen (WETS) customer load (MW)
<b>WOTSCap</b>	MVAR output of Wodonga capacitor banks. Values associated with this term are positive.
<b>YASSCap</b>	MVAR output of Yass capacitor banks. Values associated with this term are positive.
<b>YASSReac</b>	MVAR output of Yass reactors. Values associated with this term are negative.

# Glossary

This document uses many terms that have meanings defined in the National Electricity Rules (NER). The NER meanings are adopted unless otherwise specified.

Term	Definition
<b>Constraint equation</b>	These are the mathematical representations that AEMO uses to model power system limitations and FCAS requirements in National Electricity Market Dispatch Engine (NEMDE).
<b>System normal</b>	The configuration of the power system where: <ul style="list-style-type: none"><li>• All transmission elements are in service, or</li><li>• The network is operating in its normal network configuration</li></ul>
<b>TNSP</b>	Transmission Network Service Provider