

# WEM Relaxed Constraints


July 2024

Q2 2024

A summary of the total number, frequency and type of Constraints that were relaxed in order to resolve infeasible dispatch solutions







# Important notice

#### **Purpose**

Under clause 7.2.7 of the WEM Rules, AEMO must as soon as practicable after the end of each quarter, publish on the WEM Website a report summarising the total number, frequency and type of Constraints that were relaxed under clause 7.2.6 during that quarter.

#### **Disclaimer**

This document or the information in it may be subsequently updated or amended. This document does not constitute legal or business advice and should not be relied on as a substitute for obtaining detailed advice about the Wholesale Electricity Rules. AEMO has made reasonable efforts to ensure the quality of the information in this document but cannot guarantee its accuracy or completeness.

## Copyright

© 2024 Australian Energy Market Operator Limited. The material in this publication may be used in accordance with the copyright permissions on AEMO's website.

# **Relaxed Constraints**

#### 1.1 Introduction

Under clause 7.2.6 of the Wholesale Electricity Market (WEM) Rules, AEMO may "relax" Constraints used in the Central Dispatch Process in order to resolve infeasible dispatch solutions. If the WEM Dispatch Engine (WEMDE) is not able find a feasible solution, it determines which Constraints to relax<sup>1</sup> and by how much using the concept of Constraint Violation Penalty (CVP<sup>2</sup>), whereby the cost of relaxing a Constraint depends on its associated CVP value.

Under clause 7.2.7(b) of the WEM Rules, AEMO must as soon as practicable after the end of each quarter, publish on the WEM Website a report summarising the total number, frequency and type of Constraints that were relaxed under clause 7.2.6 during that quarter.

### 1.2 Summary of relaxed Constraints

Table 1 shows the breakdown of relaxed constraints by category and trading month. Note that a constraint that was relaxed in multiple intervals has been counted multiple times.

Table 1 – Breakdown of category and trading month of relaxed Constraints for Q2 of 2024

Constraint Type	Description	April	May	June	Total
Ramp Up	Formulation <sup>3</sup> Constraint used to limit Facility ramping. See section 2.4.13 of <u>WEM</u> Procedure: Dispatch Algorithm Formulation.	83	210	340	633
Minimum Enablement for ESS (Essential System Services)	Formulation Constraint used to prevent a Facility being dispatch below its ESS Enablement Minimum value. See section 2.2.15 of WEM Procedure: Dispatch Algorithm Formulation.	13	2	20	35
Defined Contingency	Constraints used to calculate the Largest Credible Supply Contingency. See section 2.4.8 of WEM Procedure: Dispatch Algorithm Formulation.	0	1	0	1
Network Constraint	Constraint corresponding to a Network Limit. See WEM Rule 7.2.4(e).	207	1333	1740	3280
Non-Co-optimised ESS (NCESS)	Constraint related to NCESS contracts. See WEM Rule 7.2.4(iA).	0	32	0	32
Other	Constraint used to meet Power System Security and Power System Reliability requirements, that do not form part of the above categories. See WEM Rule 7.2.4(f).	0	7	9	16
Total		303	1585	2109	3997

<sup>&</sup>lt;sup>1</sup> In the context of the WEM Dispatch Engine, relaxed Constraints are also called violating Constraints.

AEMO acknowledges the Traditional Owners of country throughout Australia and recognises their continuing connection to land, waters and culture. We pay respect to Elders past and present.

<sup>&</sup>lt;sup>2</sup> For more information about Constraint Violation Penalties see WEM Procedure: Dispatch Algorithm Formulation

<sup>&</sup>lt;sup>3</sup> Formulation constraints are included in the formulation of the Dispatch Algorithm (see <u>WEM Procedure: WEM Dispatch Algorithm Formulation</u>) and hence do not form part of the Constraints Library.

Table 2 contains a summary of the number of Primary Dispatch Intervals in which Constraints were relaxed.

Table 2 – Amount of Primary Dispatch Intervals with various numbers of relaxed Constraints for Q2 of 2024

N	0	1	2	3	4	5	6	7	8	9	10	>10
Number of Primary Dispatch Intervals with N relaxed Constraints	23,317	2231	397	168	73	10	4	2	1	1	0	4
Percentage of Dispatch Intervals with N relaxed Constraints	89%*	9%	2%	1%	<1%	<1%	<1%	<1%	<1%	<1%	<1%	<1%

<sup>\*</sup>The majority (89%) of intervals had no relaxed Constraints (N = 0) meaning that the Dispatch Algorithm found a feasible solution without violating any Constraints.