

MEETING OUTCOMES – AEMO PROCEDURE CHANGE WORKING GROUP (WEM)

MEETING: AEMO Procedure Change Working Group (WEM) Meeting 4
DATE: Monday, 19 February 2018
TIME: 10.00 am – 11.00 am (AWST)
LOCATION: AEMO Perth Ningaloo Room

ATTENDEES:

NAME	COMPANY
Matthew Fairclough	AEMO
Greg Ruthven	AEMO
Teresa Smit	AEMO
Patrick Peake	Perth Energy
Angelina Cox	Synergy
Dean Frost	Western Power

1. Welcome

2. Procedure Change Proposal for Power System Operating Procedure: Communications and Control

- Question – Step 2.2.2: Needs clarification as AEMO uses Western Power's SCADA?
Answer – AEMO will revise the wording in steps 2.2.2 and 1.2.2 to indicate that Participants meet their obligations to provide information to AEMO's EMS via Western Power's SCADA.
- Question – Step 2.9.1: Needs clarification as historical records are confidential?
Answer – AEMO will revise the wording to refer to the IMS Market Procedure which details the specifications regarding information.
- Question – Step 2.7.2: Why separate requirements for Facilities under a Network Control Service (NCS) contract?
Answer – A NCS contract is between a Network Operator and a Market Participant. Not all Facilities under such an arrangement will also be Balancing Facilities, and therefore AEMO may need to stipulate requirements.
- Question – Step 5: Should the data and control requirements be limited to the transmission network?
Answer – The WEM Rules do not differentiate between transmission and distribution. As such, neither can the Procedure. To fulfil its obligations, AEMO may need information that relates to the distribution network.
- Question – Step 2.9.2: Is PAX to be used as primary communications or backup? Do all new generating Facilities have PAX (this may be a decision of the generator)?
Answer – AEMO intends to use the PAX phones as the primary form of communication to Facilities with that functionality. AEMO will discuss separately with Western Power the existence of PAX phones in new Facilities.

3. Procedure Change Proposal for IMS Market Procedure

- No comments

4. Next meeting

Stakeholders will be advised of the date for the next Working Group meeting.

Action items raised at meeting – AEMO Procedure Change Working Group

Item	Topic	Action required	Responsible	By	Status
1	Directions	AEMO to advise Working Group on the status and storage of 'directions' issued in PSOP: Dispatch.	AEMO	Sep 2017	Deferred until next revision of PSOP: Dispatch